HYDRAULIC AND OTHER TABLES

for purposes of SEWERAGE & WATER-SUPPLY

By
THOMAS HENNELL
M. INST. C. E.



HYDRAULIC AND OTHER TABLES,

FOR PURPOSES OF

SEWERAGE AND WATER-SUPPLY.

BY

THOMAS HENNELL,

M. INST. C.E.

LONDON:

E. & F. N. SPON, 16, CHARING CROSS.

NEW YORK: 35, MURRAY STREET.

1884.

PREFACE.

It has been found that the Engineering Pocket Books in most general use give comparatively little information

ERRATA.

P. 29, last line, *for* "2" in 2640 *read* "1" in 2640.

P. 32, heading, *for* sewer 2 feet 6 inches × 1 foot "10" inches *read* 1 foot "8" inches.

P. 62, heading, second line, *for* Hardness (columns "3, 4, and 5" *read* "2, 3, and 4."

P. 65, first, weight per yard of 2-inch pipe, *for* "0.2.24" *read* "0.0.24."

Every precaution has been taken, as far as possible, to guard against errors both in the calculations and printing. If however, notwithstanding, any mistakes should be discovered, the author will be greatly obliged by having them pointed out to him.

6, Delahay Street, Westminster,
November 1883.

PREFACE.

It has been found that the Engineering Pocket Books in most general use give comparatively little information relating to Sewerage and Water Supply. And even the large and valuable works of the late Mr. Beardmore and others contain somewhat abridged Tables applicable to the calculations most frequently required in designing and carrying out works of moderate size.

The Tables in this book have been calculated from time to time by the author to meet his own requirements. Thinking it probable that other engineers will have experienced the same want as himself, he has now been induced to make them public. The greater part have been used in manuscript for some years; but a few additional Tables have been recently added in order to make the work more complete.

Every precaution has been taken, as far as possible, to guard against errors both in the calculations and printing. If however, notwithstanding, any mistakes should be discovered, the author will be greatly obliged by having them pointed out to him.

6, Delahay Street, Westminster,
November 1883.

CONTENTS.

DESCRIPTION AND REMARKS ON THE USE OF THE TABLES.

TABLES I. and II. show the quantities of water in gallons per foot contained in pipes, wells, tanks, &c., of given dimensions, and require no explanation.

Tables III. and IV. give the discharge in gallons per minute of water passing through sluices and over weirs under ordinary conditions. Correction is required in case of bell-mouthed or specially formed orifices, and also where there is any considerable velocity of current in approaching the outlets, but the notes at the head of the Tables, to which attention should be directed, will enable this to be made with sufficient accuracy for most practical purposes.

Table V. shows the velocity and discharge under varying conditions of flow in circular sewers and conduits, from 9 inches to 6 feet in diameter.

In designing and carrying out sewerage works, it is important to know not only the maximum carrying capacity of the sewers, but also the effect produced by the much smaller quantity which will be generally flowing through them. This is essential in order to ascertain whether flushing will be required, and if so, what quantity of water will be needed for the purpose. The Table consequently shows, not only the maximum discharge and velocity of each kind of sewer under the most favourable circumstances, but also the discharge and velocity of the same sewers when full to one-half, one quarter, and one-eighth only of their heights respectively. If a sewer

should at any time run quite full, its discharge will be somewhat less than that indicated in the fourth column, the velocity of current being in that case considerably diminished by friction against the top. With any circular conduit the velocity when full is exactly the same, and the discharge just double that when half-full; the precise figures for a sewer running full may therefore be ascertained, if required, from the third column of Table by doubling the discharge.

A velocity of 150 feet per minute, or $2\frac{1}{2}$ feet per second, is generally considered sufficient to remove all obstacles of the ordinary character found in sewers. The quantity of water required to produce this velocity in each case is given in the last column of the same Table, and will be found especially useful in designing flushing arrangements.

Table VI. gives precisely similar information for egg-shaped sewers, as Table V. for circular sewers.

Table VII. gives the discharge of pipes from $\frac{3}{8}$-inch to 3 feet diameter, when running full at various inclinations or pressures. It should be remembered that the velocity of water passing through a line of pipes of any considerable length depends not on the inclination of any particular section, but on the hydraulic gradient throughout, or ratio of head of water to length of pipe; the "head" being the difference of level between the surface at or above the upper end of the pipe, and that of the cistern or pond into which it delivers, or if it has a free outlet, the lower end of the pipe itself. This velocity, except for slightly increased friction at bends, is entirely independent of the course of the pipes, whether laid at a uniform inclination or otherwise, also whether commencing at or below the upper surface and discharging, if not freely, at or below the lower surface.

The formula which has been used in the calculations

for Tables V., VI., VII., is that known as Eytelwein's Formula, which is the basis of the tables contained in Beardmore's 'Manual of Hydrology.' The formula used in Neville's Tables, and those found in Hurst's and Molesworth's Pocket Books, gives generally rather higher results: varying in fact from about 20 per cent. higher in the case of the sharpest inclinations quoted in Tables V. and VI. herein to 5 per cent. in case of the flattest in the same Tables. And referring to Table VII., Neville's formula would give results varying from about 25 per cent. higher at the top, to from 2 to 5 per cent. lower at the foot of each page.

Except with very flat inclinations, it may therefore be fairly assumed that the results here given are somewhat within the mark, and this is especially the case with the larger sewers and pipes.

Table VIII. is intended to assist in designing the capacity of sewers, and shows at a glance the quantity of sewage, irrespective of rain and surface water, which should be allowed for given populations. In certain cases (see note at foot of Table), the allowance for rain may also be calculated on the basis of population with the help of the last column of the Table, but under ordinary circumstances this should be taken in proportion to area as shown by Table IX., next following.

Table IX. shows the quantity of water due to rainfall over given areas, and the quantities in gallons per minute, when running off at different rates of flow. The latter columns of the Table are intended for calculating the capacity of sewers ; and the second and third columns for estimating the quantity of water that can be collected from areas and gathering grounds for irrigation or water supply. The areas dealt with range from 100 square feet (representing the roof of a small building) to one square mile.

Tables X., XI., XII., are rainfall Tables, extracted principally from those prepared by Mr. Symons, for the Annual Reports of the Meteorological Society. That showing the monthly distribution at Edinburgh is, however, taken from figures contained in a valuable paper on the water supply of that city, by Mr. A. Leslie, C.E., which was read at the Institution of Civil Engineers last session.

Tables XIII. and XIV. are intended to facilitate the preparation of preliminary reports and rough estimates for works of water supply, and show the approximate dimensions of reservoirs, filter beds, main pipes, pumping machinery, &c., required for the supply of given populations. It is not of course asserted that the constant numbers assumed in the headings of the columns are universally applicable; and some few, e. g. 100 feet lift to be pumped, are necessarily arbitrary. But the differences due to variations in these conditions can be ascertained generally either by inspection or by a short calculation, and results may be thus arrived at with much greater facility than if the Tables were not available.

Table XV. gives results of analyses of potable waters. To engineers and others, not constantly or very frequently engaged in investigating the quality of water, the figures presented by an analysis convey little information without some readily available standard of comparison. This it is endeavoured to afford by means of this Table, which contains the results of analyses of well-known waters from nearly every description of source.

It is not proposed here to give any opinion on the much disputed question of the determination of organic matter in water. This was formerly attempted to be shown by the "loss on ignition" of the dissolved solid matters, and subsequently by the "oxygen required to oxidise oxidisable matter" therein. Both these methods have

been generally abandoned, but other two are still in use. The first of these, known as the combustion process, and adopted by Dr. Frankland and others, is to ascertain the quantities of carbon, nitrogen, and ammonia set free from the solid matter during combustion, and which are believed to be organic carbon and nitrogen. Dr. Frankland in his reports also gives always the nitrogen found in the solid residue as nitrates, which are mineral not organic substances, but are liable to have derived their origin from organic substance since disappeared.

The second method of determining the organic matter is called the "ammonia process," and consists in a distillation of the water by means of which the nitrogen contained in any organic substances is necessarily turned into ammonia; and this is called "free" or "albumenoid" ammonia according as it is evolved in the first or second stage of the process.

As both these methods are still in use by eminent chemists, it is thought desirable to give results of each of them. The first nine columns of the Table accordingly contain (1) the total solid matter dissolved in the water; next the portion of this total which consists of earthy salts, commonly known as "hardness," and divided into (2) "temporary" hardness, i. e. removable by boiling the water; and (3) "permanent;" (4) the total hardness; (5) the chlorine; (6) organic carbon; (7) organic nitrogen; (8) ammonia; and (9) the nitrogen contained in nitrates: all these being obtained by the combustion process. The whole of this part of the Table is from analyses made principally by Dr. Frankland, and which have been published from time to time in the Reports of the Rivers Pollution Commissioners and other official documents. In columns 10 and 11 will be found the quantities of free and albumenoid ammonia evolved by the ammonia process, from specimens of the same waters; and for the

information contained in these columns the author is indebted to Professor Wanklyn, the inventor of that process.

Tables XVI. and XVII. give the quantities of brickwork per yard in sewers, culverts, &c., and require no explanation.

Table XVIII. gives the weight per yard of cast-iron pipes adapted to different pressures of water. These weights have been arrived at not by theoretical calculation, but by a careful comparison of the specifications and recent practice of experienced engineers. They agree, however, nearly with the calculated strengths as given by Mr. Box in his Hydraulic Tables. The weights for various safe heads found in Table 14 of Beardmore's 'Manual of Hydrology,' are certainly insufficient according to recent practice.

Table XIX. gives the weights per yard of lead service pipes of five different qualities as described in the note appended to the Table.

TABLE I.—QUANTITY of WATER contained in PIPES, WELLS, and CIRCULAR TANKS, per foot in length or depth.

Diam.	Contents.	Diam.		Contents.	Diam.	Contents.	Diam.	Contents.
inches.	gals. per foot	ft.	in.	gals. per foot	feet.	gals. per foot	feet.	gals. per foot
¾	·005	1	9	15·0	11	594	90	39,758
½	·008	2	0	19·6	12	707	100	49,088
¾	·019	2	3	24·8	13	829	110	59,396
1	·034	2	6	30·7	14	962	120	70,685
1½	·076	2	9	37·1	15	1,104	130	82,956
2	·135	3	0	44·2	16	1,256	140	96,211
2½	·212	3	3	51·8	17	1,418	150	110,447
3	·305	3	6	60·2	18	1,590	160	125,664
4	·54	3	9	69·0	19	1,772	170	141,862
5	·85	4	0	78·5	20	1,963	180	159,044
6	1·22	4	6	99·4	25	3,068	190	177,206
7	1·66	5	0	122·7	30	4,418	200	196,350
8	2·17	5	6	148·5	35	6,013	250	306,796
9	2·75	6	0	176·7	40	7,854	300	441,788
10	3·39	6	6	207·4	45	9,940	350	601,322
11	4·12	7	0	240·5	50	12,272	400	785,400
12	4·91	7	6	276·1	55	14,850	500	1,227,190
13	5·75	8	0	314·2	60	17,671	600	1,767,150
14	6·67	8	6	354·7	65	20,740	700	2,405,290
15	7·67	9	0	397·6	70	24,053	800	3,141,600
16	8·72	9	6	443·0	75	27,611	900	3,975,750
18	11·04	10	0	490·9	80	31,416	1000	4,908,750

TABLE II.—QUANTITY of WATER contained in SQUARE CISTERNS or TANKS, per foot in depth.

Length of Side.		Contents.	Length of Side.		Contents.	Length of Side.	Contents.	Length of Side.	Contents.
ft.	in.	gals. per foot	ft.	in.	gals. per foot	feet	gals. per foot	feet	gals. per foot
1	0	6·25	6	0	205	25	3,906	90	50,625
1	6	14·06	7	0	306	30	5,625	100	62,500
2	0	25·00	8	0	400	35	7,756	125	156,250
2	6	39·06	9	0	506	40	10,000	150	140,625
3	0	56·25	10	0	625	45	12,656	200	250,000
3	6	77·56	11	0	756	50	15,625	300	562,500
4	0	100·00	12	0	900	60	20,500	400	1,000,000
4	6	126·56	15	0	1,406	70	30,625	500	1,562,500
5	0	156·25	20	0	2,500	80	40,000	1000	6,250,000

TABLE III.—FLOW of WATER through SLUICES and OPENINGS.

NOTE.—The "Head of Water" in the Table must represent the depth from the surface to the centre of the opening; or if the opening be submerged, then the difference of level between the surfaces above and below.

If the opening be bell-mouthed, or be a sluice having curved side walls properly tapering inwards to the narrowest part, the discharge will be greater than that shown by the Table, to the extent of, in case of the best form of opening, about 50 per cent.

Head of Water.		Discharge per Square Foot in Area of Opening.	Head of Water.		Discharge per Square Foot in Area of Opening.	Head of Water.		Discharge per Square Foot in Area of Opening.	Head of Water.		Discharge per Square Foot in Area of Opening.
ft.	in.	gals. per minute	ft.	in.	gals. per minute	ft.	in.	gals. per minute	ft.	in.	gals. per minute
	½	382	2	3	2,813	8	3	5,385	16	6	7,616
	1	541	2	6	2,964	8	6	5,466	17	0	7,731
	1½	663	2	9	3,110	8	9	5,546	17	6	7,844
	2	765	3	0	3,248	9	0	5,625	18	0	7,956
	2½	856	3	3	3,379	9	3	5,702	18	6	8,064
	3	937	3	6	3,507	9	6	5,779	19	0	8,173
	3½	1,014	3	9	3,631	9	9	5,854	19	6	8,280
	4	1,082	4	0	3,751	10	0	5,929	20	0	8,385
	5	1,210	4	3	3,865	10	3	6,004	21	0	8,590
	6	1,326	4	6	3,977	10	6	6,075	22	0	8,796
	7	1,432	4	9	4,086	10	9	6,148	23	0	8,991
	8	1,530	5	0	4,192	11	0	6,219	24	0	9,184
	9	1,624	5	3	4,295	11	3	6,288	25	0	9,375
	10	1,712	5	6	4,398	11	6	6,358	26	0	9,558
	11	1,794	5	9	4,495	11	9	6,427	27	0	9,744
1	0	1,875	6	0	4,592	12	0	6,495	28	0	9,920
1	1	1,951	6	3	4,687	12	6	6,628	30	0	10,269
1	2	2,025	6	6	4,779	13	0	6,759	32	0	10,605
1	3	2,096	6	9	4,872	13	6	6,888	34	0	10,933
1	4	2,165	7	0	4,960	14	0	7,015	36	0	11,253
1	5	2,231	7	3	5,048	14	6	7,139	38	0	11,557
1	6	2,296	7	6	5,135	15	0	7,262	40	0	11,857
1	9	2,480	7	9	5,219	15	6	7,382	45	0	12,577
2	0	2,651	8	0	5,302	16	0	7,502	50	0	13,256

TABLE IV.—FLOW of WATER over WEIRS.

NOTE.—The "Depth" must represent difference in level between the sill of the weir and the surface of still water above it. If the water approaches the weir with a current having a perceptible velocity, the discharge will be greater than that shown by the Table to an extent depending on the velocity; a velocity of 2 feet per second will be equivalent generally to about half an inch, and a velocity of 3 feet per second to about three-quarters of an inch additional depth.

Depth.	Discharge per Inch in Width.	Depth.	Discharge per Inch in Width.	Depth.	Discharge per Inch in Width.	Depth.		Discharge per Inch in Width.
inches	gals. per min.	inches	gals. per min.	inches	gals. per min.	ft.	in.	gals. per min.
¼	·334	4⅛	22·37	10¼	87·5	2	1	334
5/16	·467	4¼	23·39	10½	90·8	2	2	354
⅜	·613	4⅜	24·44	10¾	94·1	2	3	374
½	·944	4½	25·49	11	97·4	2	4	395
5/8	1·329	4⅝	26·56	11¼	100·7	2	5	417
¾	1·734	4¾	27·64	11½	104·1	2	6	439
⅞	2·185	4⅞	28·74	11¾	107·5	2	7	461
1	2·670	5	29·85	12	111·0	2	8	483
1⅛	3·185	5⅛	30·97	12½	118·0	2	9	506
1¼	3·818	5¼	32·12	13	125·1	2	10	529
1⅜	4·305	5⅜	33·26	13½	132·5	2	11	553
1½	4·905	5½	34·44	14	139·8	3	0	577
1⅝	5·531	5⅝	35·62	14½	147·4	3	1	601
1¾	6·167	5¾	36·85	15	155·1	3	2	625
1⅞	6·855	5⅞	38·02	15½	163·0	3	3	650
2	7·552	6	39·24	16	170·9	3	4	675
2⅛	8·27	6¼	41·72	16½	179·0	3	5	701
2¼	9·01	6½	44·25	17	187·1	3	6	727
2⅜	9·77	6¾	46·82	17½	195·5	3	7	753
2½	10·55	7	49·45	18	203·9	3	8	779
2⅝	11·36	7¼	52·12	18½	212·3	3	9	806
2¾	12·18	7½	54·84	19	221·1	3	10	833
2⅞	13·02	7¾	57·61	19½	229·8	3	11	860
3	13·87	8	60·41	20	238·8	4	0	888
3⅛	14·75	8¼	62·54	20½	247·6	4	1	915
3¼	15·64	8½	66·17	21	256·9	4	2	944
3⅜	16·55	8¾	69·11	21½	265·9	4	3	972
3½	17·48	9	72·09	22	275·5	4	4	1000
3⅝	18·42	9¼	75·12	22½	284·8	4	6	1060
3¾	19·39	9½	78·18	23	294·4	4	8	1120
3⅞	20·37	9¾	81·29	23½	303·9	4	10	1180
4	21·36	10	84·43	24	313·9	5	0	1240

TABLE V.—VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 9 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. (1⅛ Inch.)		One-quarter. (2¼ Inches.)		One-half. (4½ Inches.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons.	feet	gallons	gallons
1 in	20	264	300	58	420	225	550	755	600	1535	..
1 „	30	176	246	48	344	195	447	615	490	1245	..
1 „	40	132	212	40	296	158	387	530	424	1085	..
1 „	50	105·6	190	37	266	143	346	475	380	975	..
1 „	66	80	166	33	230	122	302	415	330	845	..
1 „	80	66	151	30	209	112	275	377	300	768	30
1 „	100	52·8	134	26	187	100	244	330	267	682	40
1 „	132	40	117	22	164	88	213	293	232	594	60
1 „	165	32	105	20	146	78	190	261	208	532	85
1 „	200	26·4	95	18	133	71	173	238	190	487	125
1 „	264	20	83	16	115	62	151	207	165	422	200
1 „	330	16	74	14	103	55	134	184	148	378	..
1 „	440	12	64	12	89	48	115	158	128	327	..
1 „	528	10	58	11	82	44	106	146	116	291	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 12 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (1½ Inch.)		One-quarter. (3 Inches.)		One-half. (6 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 30	176	284	98	396	380	520	1,275	**565**	**2580**	..
1 „ 40	132	247	86	342	330	446	1,100	**490**	**2235**	..
1 „ 50	105·6	220	76	303	292	400	980	**438**	**2000**	..
1 „ 66	80	192	66	268	260	348	850	**380**	**1730**	..
1 „ 80	66	173	60	243	235	316	725	**346**	**1580**	33
1 „ 100	52·8	155	53	220	212	282	690	**309**	**1410**	45
1 „ 132	40	135	46	188	181	246	600	**270**	**1230**	69
1 „ 165	32	121	42	169	162	220	540	**241**	**1100**	96
1 „ 200	26·4	110	38	151	145	200	490	**219**	**1000**	135
1 „ 264	20	96	33	134	130	174	425	**190**	**865**	212
1 „ 330	16	85	29	119	115	155	380	**170**	**780**	320
1 „ 440	12	74	25	103	99	135	331	**147**	**670**	..
1 „ 528	10	67	23	94	90	123	300	**135**	**615**	..
1 „ 660	8	60	21	84	81	110	270	**120**	**550**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 15 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (1¼ Inch.)		One-quarter. (3¾ Inches.)		One-half. (7½ Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 40	132	278	150	385	592	500	1900	**547**	**3900**	..
1 „ 50	105·6	250	135	342	526	446	1700	**488**	**3480**	..
1 „ 66	80	218	117	299	460	386	1470	**426**	**3030**	..
1 „ 80	66	196	105	272	418	352	1340	**386**	**2750**	35
1 „ 100	52·8	176	94	242	372	316	1204	**346**	**2460**	50
1 „ 132	40	153	82	211	325	274	1044	**301**	**2140**	76
1 „ 165	32	137	73	189	291	245	933	**268**	**1910**	106
1 „ 200	26·4	125	67	171	263	223	888	**244**	**1737**	146
1 „ 264	20	109	58	149	229	193	735	**213**	**1516**	225
1 „ 330	16	97	52	134	206	174	662	**190**	**1350**	330
1 „ 440	12	83	44	115	177	150	571	**165**	**1175**	567
1 „ 528	10	76	41	105	162	137	520	**150**	**1068**	..
1 „ 660	8	68	36	95	146	123	468	**134**	**954**	..
1 „ 880	6	60	32	82	126	105	400	**116**	**824**	..

Velocity and Discharge per Minute in Circular Sewers, with Water flowing at various depths.

Diameter 18 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (2¼ Inches.)		One-quarter. (4½ Inches.)		One-half. (9 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 50	105·6	270	210	382	830	488	2684	536	5500	..
1 „ 66	80	234	182	326	684	426	2380	466	4776	..
1 „ 80	66	213	164	290	625	386	2120	423	4336	38
1 „ 100	52·8	190	147	265	573	346	1903	379	3885	54
1 „ 132	40	166	129	230	497	301	1655	330	3382	83
1 „ 165	32	148	115	208	450	268	1474	295	3024	116
1 „ 200	26·4	135	105	191	414	244	1342	268	2747	157
1 „ 264	20	117	91	163	340	213	1171	233	2388	243
1 „ 330	16	105	81	145	312	190	1046	209	2140	353
1 „ 440	12	91	70	126	272	165	907	180	1845	580
1 „ 528	10	82	63	116	260	150	825	165	1691	807
1 „ 660	8	73	57	104	225	135	740	147	1507	..
1 „ 880	6	65	50	89	192	116	640	127	1302	..
1 „ 1056	5	58	45	81	170	106	585	116	1190	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 1 Foot 9 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. ($2\frac{5}{8}$ Inches.)		One-quarter. ($5\frac{1}{4}$ Inches.)		One-half. ($10\frac{1}{2}$ Inches.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	50	105·6	292	306	406	1200	524	3930	**582**	**8150**	..
1 „	66	80	254	266	354	1050	456	3420	**506**	**7080**	..
1 „	80	66	230	241	322	950	414	3115	**460**	**6440**	42
1 „	100	52·8	206	216	288	849	370	2775	**411**	**5754**	58
1 „	132	40	179	188	251	740	322	2415	**358**	**5012**	89
1 „	165	32	160	168	224	661	288	2160	**320**	**4480**	125
1 „	200	26·4	146	153	203	599	262	1965	**291**	**4074**	167
1 „	264	20	127	133	177	524	228	1710	**253**	**3542**	257
1 „	330	16	113	119	158	462	204	1530	**226**	**3162**	375
1 „	440	12	98	103	137	404	176	1320	**196**	**2744**	600
1 „	528	10	89	94	125	369	161	1207	**179**	**2506**	830
1 „	660	8	80	84	112	330	144	1080	**160**	**2240**	1270
1 „	880	6	69	72	97	286	125	937	**138**	**1932**	..
1 „	1056	5	63	66	89	263	114	855	**126**	**1770**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 2 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (3 Inches.)		One-quarter. (6 Inches.)		One-half. (1 Foot.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	270	370	378	1450	492	4820	538	9800	.
1 „ 80	66	246	338	344	1324	446	4370	490	8820	45
1 „ 100	52·8	220	301	307	1182	398	3900	438	8000	62
1 „ 132	40	191	262	284	1092	348	3410	381	6950	2[illegible]
1 „ 165	32	171	234	239	920	311	3048	340	6200	133
1 „ 200	26·4	155	212	217	835	282	2764	309	5640	177
1 „ 264	20	135	185	189	728	246	2411	269	4900	274
1 „ 330	16	121	166	169	650	220	2156	241	4400	397
1 „ 440	12	105	145	146	562	190	1862	208	3800	630
1 „ 528	10	96	131	134	515	174	1705	190	3470	850
1 „ 660	8	85	116	119	458	155	1519	170	3100	1300
1 „ 880	6	74	101	103	396	134	1313	148	2700	..
1 „ 1056	5	68	93	95	366	123	1205	134	2485	..
1 „ 1320	4	60	82	84	323	110	1078	120	2200	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 2 Feet 3 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (3⅜ Inch.)		One-quarter. (6¾ Inches.)		One-half. (1 Foot 1½ Inch.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	286	500	400	1950	520	6420	**570**	**13,180**	..
1 „ 80	66	261	450	364	1772	473	5830	**520**	**11,900**	48
1 „ 100	52·8	232	403	326	1587	423	5220	**464**	**10,728**	66
1 „ 132	40	203	353	284	1383	368	4541	**404**	**9,340**	101
1 „ 165	32	181	314	253	1232	329	4060	**361**	**8,346**	141
1 „ 200	26·4	165	287	230	1120	298	3677	**328**	**7,583**	187
1 „ 264	20	143	248	200	974	260	3205	**285**	**6,589**	289
1 „ 330	16	128	222	179	872	233	2875	**255**	**5,895**	419
1 „ 440	12	111	193	155	755	201	2480	**221**	**5,109**	660
1 „ 528	10	102	177	142	691	184	2270	**202**	**4,670**	880
1 „ 660	8	92	160	126	614	164	2024	**180**	**4,162**	1340
1 „ 880	6	78	135	109	531	142	1752	**157**	**3,620**	2250
1 „ 1056	5	71	123	100	487	130	1604	**143**	**3,300**	..
1 „ 1320	4	64	111	89	433	116	1431	**128**	**2,959**	..

Velocity and Discharge per Minute in Circular Sewers, with Water flowing at various depths.

Diameter 2 Feet 6 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (3¼ Inches.)		One-quarter. (7½ Inches.)		One-half. (1 Foot 3 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	302	650	422	2520	550	8420	**602**	**17,150**	42
1 „ 100	52·8	246	529	344	2067	447	6843	**486**	**13,851**	70
1 „ 132	40	214	460	299	1797	389	5955	**426**	**12,141**	106
1 „ 165	32	191	411	267	1505	347	5312	**381**	**10,858**	148
1 „ 200	26·4	174	374	243	1460	315	4823	**345**	**9,832**	197
1 „ 264	20	151	325	211	1268	275	4210	**301**	**8,578**	303
1 „ 330	16	135	290	189	1136	246	3766	**269**	**7,666**	430
1 „ 440	12	117	251	164	986	213	3261	**233**	**6,640**	690
1 „ 528	10	107	230	150	901	194	2970	**213**	**6,070**	900
1 „ 660	8	96	206	134	805	174	2664	**190**	**5,415**	1380
1 „ 880	6	82	176	115	691	150	2296	**165**	**4,702**	2270
1 „ 1056	5	75	161	105	631	137	2097	**150**	**4,275**	3500
1 „ 1320	4	68	146	94	565	123	1883	**134**	**3,819**	..
1 „ 1760	3	58	125	82	493	106	1630	**116**	**3,320**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 2 Feet 9 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. (4⅛ Inches.)		One-quarter. (8¼ In.hes.)		One-half. (1 Foot 4½ Inches.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	66	80	316	822	444	3232	576	10,675	**632**	**21,800**	..
1 „	100	52·8	258	671	360	2621	469	8,690	**513**	**17,698**	74
1 „	132	40	224	582	313	2279	407	7,542	**447**	**15,420**	111
1 „	165	32	200	520	280	2038	365	6,763	**399**	**13,765**	155
1 „	200	26·4	183	476	255	1856	331	6,133	**363**	**12,523**	207
1 „	264	20	158	411	222	1616	288	5,337	**316**	**10,902**	316
1 „	330	16	142	369	198	1441	258	4,781	**282**	**9,729**	450
1 „	440	12	124	322	172	1252	223	4,132	**244**	**8,418**	713
1 „	528	10	112	291	157	1143	203	3,761	**223**	**7,693**	940
1 „	660	8	100	260	140	1019	182	3,374	**200**	**6,900**	1420
1 „	880	6	87	226	121	881	158	2,928	**173**	**5,970**	2300
1 „	1056	5	79	207	110	801	144	2,668	**158**	**5,450**	3300
1 „	1320	4	71	185	99	753	129	2,390	**141**	**4,864**	..
1 „	1760	3	62	166	86	626	111	2,060	**122**	**4,210**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 3 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (4½ Inches.)		One-quarter. (9 Inches.)		One-half (1 Foot 6 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	66 80	332	1027	462	3999	604	13,290	**660**	**27,100**	..
1 „	100 52·8	269	832	376	3255	489	10,760	**534**	**21,926**	78
1 „	132 40	235	727	328	2839	426	9,370	**464**	**19,052**	116
1 „	165 32	210	650	284	2458	380	8,360	**416**	**17,080**	162
1 „	200 26·4	190	588	266	2302	346	7,610	**380**	**15,603**	217
1 „	264 20	166	514	231	1999	302	6,640	**330**	**13,550**	329
1 „	330 16	148	458	207	1792	268	5,900	**296**	**12,154**	468
1 „	440 12	128	396	179	1549	230	5,060	**256**	**10,500**	738
1 „	528 10	117	363	164	1419	212	4,660	**232**	**9,526**	1000
1 „	660 8	104	322	146	1264	190	4,180	**208**	**8,540**	1460
1 „	880 6	91	281	126	1091	165	3,630	**181**	**7,432**	2330
1 „	1056 5	83	257	115	995	151	3,320	**165**	**6,774**	3300
1 „	1320 4	74	229	103	891	134	2,950	**148**	**6,055**	..
1 „	1760 3	64	198	89	770	115	2,530	**128**	**5,255**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 3 Feet 6 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (5¼ Inches.)		One-quarter. (10½ Inches.)		One-half. (1 Foot 9 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	359	1508	501	5887	651	19,530	**713**	**39,860**	..
1 „ 132	40	253	1062	355	4171	460	13,800	**504**	**28,200**	126
1 „ 200	26·4	206	865	288	3384	374	11,220	**404**	**22,600**	235
1 „ 264	20	179	752	251	2949	325	9,750	**356**	**19,930**	345
1 „ 330	16	160	672	224	2632	291	8,730	**319**	**17,850**	504
1 „ 440	12	139	584	194	2279	252	7,560	**276**	**15,430**	790
1 „ 528	10	126	529	177	2080	230	6,900	**252**	**14,100**	1045
1 „ 660	8	113	475	158	1856	206	6,180	**225**	**12,590**	1500
1 „ 880	6	98	412	136	1598	178	5,340	**195**	**10,900**	2430
1 „ 1056	5	90	378	125	1469	162	4,860	**178**	**9,960**	3360
1 „ 1320	4	80	336	112	1316	145	4,350	**159**	**8,900**	5080
1 „ 1760	3	69	290	97	1140	126	3,780	**138**	**7,720**	..
1 „ 2112	2·5	63	265	88	1040	115	3,450	**126**	**7,050**	..
1 „ 2640	2	56	235	79	930	103	3,090	**113**	**6,320**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 4 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (6 Inches.)		One-quarter. (1 Foot.)		One-half. (2 Feet.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	384	2110	536	8240	695	27,240	**764**	**55,780**	..
1 „ 132	40	271	1490	372	5720	492	19,300	**539**	**39,340**	..
1 „ 200	26·4	220	1210	302	4640	400	15,680	**438**	**31,970**	245
1 „ 264	20	192	1055	268	4120	348	13,640	**382**	**27,890**	375
1 „ 330	16	171	940	238	3658	310	12,150	**340**	**24,820**	535
1 „ 440	12	148	814	204	3136	269	10,540	**294**	**21,460**	830
1 „ 528	10	134	737	186	2860	246	9,650	**269**	**19,650**	1100
1 „ 660	8	121	665	166	2550	220	8,620	**241**	**17,600**	1580
1 „ 880	6	105	577	146	2244	190	7,450	**208**	**15,180**	2530
1 „ 1056	5	96	528	134	2059	174	6,820	**191**	**13,940**	3500
1 „ 1320	4	86	473	119	1829	155	6,075	**170**	**12,410**	5100
1 „ 1760	3	74	407	102	1568	134	5,260	**147**	**10,730**	..
1 „ 2112	2·5	67	368	93	1430	123	4,825	**135**	**9,830**	..
1 „ 2640	2	60	330	83	1275	110	4,310	**121**	**8,800**	..

Velocity and Discharge per Minute in Circular Sewers, with Water flowing at various depths.

Diameter 5 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (7¼ Inches.)		One-quarter. (1 Foot 3 Inches.)		One-half. (2 Feet 6 Inches).		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	428	3680	600	14,400	776	47,300	**852**	**97,180**	..
1 „ 132	40	302	2600	422	10,150	548	33,400	**602**	**68,640**	..
1 „ 200	26·4	246	2115	342	8,220	446	27,180	**488**	**55,630**	..
1 „ 264	20	214	1840	300	7,200	388	23,650	**426**	**48,590**	420
1 „ 330	16	194	1670	268	6,430	348	21,210	**380**	**43,320**	590
1 „ 440	12	166	1430	230	5,530	300	18,280	**330**	**37,620**	920
1 „ 528	10	151	1300	211	5,075	274	16,700	**301**	**34,320**	1,220
1 „ 660	8	136	1170	189	4,540	246	15,000	**268**	**30,550**	1,730
1 „ 880	6	117	1000	164	3,945	213	12,980	**232**	**26,450**	2,800
1 „ 1056	5	107	920	150	3,600	194	11,820	**213**	**24,300**	3,600
1 „ 1320	4	97	835	134	3,215	174	10,600	**190**	**21,660**	5,380
1 „ 1760	3	83	715	115	2,765	150	9,140	**165**	**18,860**	9,040
1 „ 2112	2·5	75	650	105	2,540	137	8,350	**151**	**17,160**	12,800
1 „ 2640	2	68	585	90	2,270	123	7,500	**134**	**15,275**	..

VELOCITY and DISCHARGE per MINUTE in CIRCULAR SEWERS, with Water flowing at various depths.

Diameter 6 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (9 Inches.)		One-quarter. (I Foot 6 Inches.)		One-half. (3 Feet.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	468	5790	652	22,580	852	75,200	**932**	**153,000**	..
1 „ 132	40	332	4110	462	16,000	602	53,120	**660**	**108,400**	..
1 „ 200	26·4	270	3340	382	13,140	488	43,060	**536**	**88,040**	..
1 „ 264	20	234	2895	326	11,290	426	37,600	**466**	**76,500**	455
1 „ 330	16	210	2610	290	10,040	380	33,535	**418**	**68,660**	640
1 „ 440	12	182	2250	252	8,720	330	29,120	**360**	**59,130**	980
1 „ 528	10	166	2055	232	8,000	301	26,560	**330**	**54,200**	1,320
1 „ 660	8	148	1830	208	7,200	270	23,830	**294**	**48,290**	1,890
1 „ 880	6	129	1600	178	6,160	232	20,480	**254**	**41,740**	2,950
1 „ 1056	5	117	1448	162	5,645	212	18,800	**233**	**38,250**	3,850
1 „ 1320	4	105	1300	145	5,020	190	16,770	**209**	**34,330**	5,670
1 „ 1760	3	91	1126	126	4,360	165	14,560	**180**	**29,560**	9,340
1 „ 2112	2·5	83	1027	116	4,000	150	13,280	**165**	**27,100**	13,200
2 „ 2640	2	74	917	104	3,600	135	11,915	**147**	**24,140**	..

TABLE VI.—VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 2 Feet × 1 Foot 4 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (3 Inches.)		One-quarter. (6 Inches.)		One-half. (1 Foot.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 50	105·6	295	223	380	790	480	2720	**595**	**6910**	..
1 „ 66	80	257	196	331	686	417	2360	**468**	**5440**	..
1 „ 100	52·8	210	160	268	556	339	1921	**381**	**4430**	38
1 „ 132	40	183	139	234	486	295	1674	**331**	**3850**	60
1 „ 165	32	163	124	210	436	264	1496	**297**	**3450**	80
1 „ 200	26·4	148	112	190	395	240	1360	**270**	**3138**	120
1 „ 264	20	129	98	166	346	208	1180	**234**	**2720**	210
1 „ 330	16	116	88	148	305	186	1056	**210**	**2440**	330
1 „ 440	12	99	76	128	268	162	918	**182**	**2115**	620
1 „ 528	10	91	69	117	243	148	838	**166**	**1925**	920
1 „ 660	8	81	62	105	216	132	748	**148**	**1725**	..
1 „ 880	6	70	53	91	189	114	646	**120**	**1490**	..
1 „ 1056	5	64	47	83	172	104	590	**117**	**1360**	..
1 „ 1320	4	58	44	74	153	93	527	**105**	**1220**	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 2 Feet 3 Inches × 1 Foot 6 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. (3⅜ Inches.)		One-quarter. (6¾ Inches.)		One-half. (1 Foot 1½ Inch.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	50	105·6	312	300	402	1054	508	4480	**572**	**8400**	..
1 „	66	80	271	260	350	920	443	3900	**497**	**7310**	..
1 „	100	52·8	221	212	285	747	360	3175	**404**	**5940**	41
1 „	132	40	192	185	248	650	314	2770	**352**	**5180**	63
1 „	165	32	172	167	222	582	280	2470	**314**	**4620**	85
1 „	200	26·4	156	150	201	527	254	2240	**286**	**4200**	120
1 „	264	20	135	130	176	460	222	1960	**248**	**3650**	210
1 „	330	16	121	116	156	409	198	1750	**222**	**3265**	330
1 „	440	12	105	101	136	356	172	1512	**192**	**2824**	610
1 „	528	10	97	93	124	325	156	1380	**176**	**2590**	900
1 „	660	8	86	83	111	290	140	1235	**157**	**2310**	2000
1 „	880	6	74	71	96	250	121	1067	**126**	**2000**	..
1 „	1056	5	68	65	88	230	111	980	**124**	**1824**	..
1 „	1320	4	61	59	78	204	99	874	**111**	**1633**	..

Velocity and Discharge per Minute in Egg-shaped Sewers, with Water flowing at various depths.

Sewer 2 Feet 6 Inches × 1 Foot 10 Inches.

Inclination.		Depth of Flow in proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (3¾ inches.)		One-quarter. (7½ inches.)		One-half. (1 Foot 3 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	280	338	371	1203	467	4138	**522**	**9500**	..
1 „ 100	52·8	226	272	301	972	369	3350	**424**	**7700**	43
1 „ 132	40	198	238	261	846	330	2924	**369**	**6700**	65
1 „ 165	32	176	214	236	764	296	2620	**330**	**6000**	90
1 „ 200	26·4	160	193	212	687	268	2375	**300**	**5450**	125
1 „ 264	20	140	169	186	601	233	2069	**261**	**4750**	210
1 „ 330	16	124	150	165	534	209	1852	**235**	**4280**	335
1 „ 440	12	108	131	143	463	180	1598	**202**	**3670**	600
1 „ 528	10	99	120	131	424	165	1462	**185**	**3350**	890
1 „ 660	8	88	107	118	382	148	1311	**165**	**3000**	1500
1 „ 880	6	77	93	101	328	128	1132	**143**	**2600**	..
1 „ 1056	5	70	84	92	300	117	1034	**131**	**2380**	..
1 „ 1320	4	62	74	82	266	105	926	**118**	**2140**	..
1 „ 1760	3	54	65	71	230	90	800	**101**	**1834**	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 2 Feet 9 Inches × 1 Foot 10 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. (4½ Inches.)		One-quarter. (8¼ Inches.)		One-half. (1 Foot 4½ Inches.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	66	80	300	432	387	1518	489	5230	550	12,050	..
1 „	100	52·8	243	350	313	1230	402	4300	446	9,800	45
1 „	132	40	212	305	274	1077	345	3690	389	8,550	70
1 „	165	32	190	274	244	956	308	3300	348	7,720	100
1 „	200	26·4	172	248	222	870	284	3040	316	6,950	130
1 „	264	20	150	216	194	760	244	2610	274	6,020	215
1 „	330	16	134	192	172	674	218	2333	246	5,400	345
1 „	440	12	116	168	150	588	190	2033	214	4,700	588
1 „	528	10	106	153	137	538	172	1840	194	4,270	880
1 „	660	8	95	137	122	478	154	1650	174	3,860	1440
1 „	880	6	82	118	106	411	133	1420	150	3,300	3300
1 „	1056	5	75	108	97	380	122	1310	137	3,010	..
1 „	1320	4	67	96	86	337	109	1166	123	2,700	..
1 „	1760	3	58	84	75	294	95	1016	107	2,350	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 3 Feet × 2 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (4¼ Inches.)		One-quarter. (9 Inches.)		One-half. (1 Foot 6 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 66	80	313	540	404	1880	510	6500	**574**	**14,900**	..
1 „ 100	52·8	255	437	322	1504	414	5280	**467**	**12,120**	..
1 „ 132	40	221	380	286	1335	361	4600	**407**	**10,550**	75
1 „ 165	32	198	338	256	1200	324	4130	**364**	**9,450**	100
1 „ 200	26·4	180	309	228	1064	293	3735	**330**	**8,570**	135
1 „ 264	20	157	270	202	940	255	3250	**286**	**7,450**	215
1 „ 330	16	139	238	180	840	228	2910	**257**	**6,680**	350
1 „ 440	12	121	208	156	728	198	2525	**222**	**5,770**	590
1 „ 528	10	111	190	143	668	180	2300	**203**	**5,270**	870
1 „ 660	8	99	169	128	600	162	2065	**182**	**4,725**	1400
1 „ 880	6	86	147	111	517	140	1785	**157**	**4,075**	2800
1 „ 1056	5	78	135	101	470	128	1620	**143**	**3,730**	..
1 „ 1320	4	70	120	90	420	114	1455	**128**	**3,340**	..
1 „ 1760	3	61	105	78	364	99	1262	**111**	**2,885**	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 3 Feet 3 Inches × 2 Feet 2 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (4⅞ Inches.)		One-quarter. (9¾ Inches.)		One-half. (1 Foot 7½ Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons.
1 in 66	80	326	655	421	2300	532	7975	**598**	**18,240**	..
1 „ 100	52·8	264	531	341	1865	432	6475	**490**	**14,935**	..
1 „ 132	40	230	462	298	1630	376	5635	**422**	**12,870**	75
1 „ 165	32	207	416	266	1455	336	5040	**378**	**11,530**	100
1 „ 200	26·4	186	374	241	1320	304	4560	**344**	**10,490**	135
1 „ 264	20	161	324	210	1150	266	3990	**299**	**9,120**	220
1 „ 330	16	143	287	187	1023	238	3565	**267**	**8,140**	350
1 „ 440	12	126	253	164	897	206	3090	**232**	**7,075**	590
1 „ 528	10	115	231	149	825	187	2800	**211**	**6,435**	865
1 „ 660	8	103	207	133	727	168	2520	**189**	**5,765**	1390
1 „ 880	6	89	179	115	630	145	2170	**162**	**4,940**	2700
1 „ 1056	5	81	163	105	574	133	1995	**150**	**4,560**	4550
1 „ 1320	4	71	144	93	511	119	1785	**133**	**4,055**	..
1 „ 1760	3	63	127	82	448	103	1540	**116**	**3,540**	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewer 3 Feet 6 Inches × 2 Feet 4 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (5¼ Inches.)		One-quarter. (10½ Inches.)		One-half. (1 Foot 9 Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 100	52·8	275	642	355	2260	448	7760	504	17,950	..
1 „ 132	40	240	560	300	1900	390	6760	440	15,660	80
1 „ 165	32	214	500	276	1740	350	6000	394	14,030	110
1 „ 200	26·4	195	455	251	1600	317	5490	357	12,700	140
1 „ 264	20	170	396	218	1370	275	4780	312	11,100	220
1 „ 330	16	152	355	196	1240	247	4280	278	9,900	355
1 „ 440	12	132	308	170	1080	215	3730	242	8,600	600
1 „ 528	10	120	280	154	950	195	3380	220	7,830	865
1 „ 660	8	107	250	138	870	175	3000	197	7,015	1380
1 „ 880	6	93	217	120	760	151	2620	170	6,050	2550
1 „ 1056	5	85	198	109	690	138	2390	157	5,500	4200
1 „ 1320	4	76	177	98	623	124	2140	139	4,950	..
1 „ 1760	3	66	154	85	540	108	1870	121	4,300	..
1 „ 2640	2	53	124	69	437	87	1500	98	3,510	..

Velocity and Discharge per Minute in Egg-shaped Sewers, with Water flowing at various depths.

Sewer 3 Feet 9 Inches × 2 Feet 6 Inches.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (5⅜ Inches.)		One-quarter. (11¼ Inches.)		One-half. (1 Foot 10½ Inches.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 100	52·8	284	758	367	2665	464	9190	**521**	**21,200**	..
1 „ 132	40	248	662	319	2315	404	8000	**454**	**18,460**	80
1 „ 165	32	222	592	286	2075	360	7130	**405**	**16,470**	115
1 „ 200	26·4	201	536	260	1890	328	6495	**369**	**15,000**	145
1 „ 264	20	175	467	226	1640	285	5645	**321**	**13,050**	225
1 „ 330	16	157	418	201	1460	255	5050	**287**	**11,670**	360
1 „ 440	12	136	362	175	1270	221	4375	**249**	**10,125**	610
1 „ 528	10	124	331	160	1160	202	4000	**227**	**9,230**	865
1 „ 660	8	111	296	143	1038	180	3565	**203**	**8,240**	1350
1 „ 880	6	96	256	124	901	156	3090	**176**	**7,155**	2550
1 „ 1056	5	87	234	113	820	143	2830	**160**	**6,520**	3850
1 „ 1320	4	78	209	101	730	127	2525	**143**	**5,825**	..
1 „ 1760	3	68	181	87	635	110	2188	**124**	**5,060**	..
1 „ 2640	2	55	148	71	515	90	1782	**102**	**4,120**	..

Velocity and Discharge per Minute in Egg-shaped Sewers, with Water flowing at various depths.

Sewer 4 Feet × 2 Feet 8 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth. (6 Inches.)		One-quarter. (1 Foot.)		One-half. (2 Feet.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	100	52·8	294	884	380	3150	479	10,850	**537**	**25,000**	..
1 „	132	40	255	780	330	2740	417	9,440	**468**	**21,760**	80
1 „	165	32	226	680	295	2450	372	8,420	**420**	**19,500**	120
1 „	200	26·4	208	635	268	2220	339	7,675	**380**	**17,670**	150
1 „	264	20	181	550	234	1940	295	6,680	**332**	**15,430**	225
1 „	330	16	162	490	208	1725	264	5,980	**297**	**13,800**	360
1 „	440	12	140	430	180	1500	228	5,160	**256**	**11,900**	610
1 „	528	10	128	390	165	1350	208	4,720	**234**	**10,880**	860
1 „	660	8	113	340	148	1230	186	4,210	**210**	**9,750**	1350
1 „	880	6	99	300	128	1065	162	3,668	**182**	**8,460**	2500
1 „	1056	5	90	275	117	970	148	3,340	**166**	**7,720**	4000
1 „	1320	4	81	245	104	863	132	2,990	**148**	**6,900**	..
1 „	1760	3	70	210	90	750	114	2,580	**128**	**5,950**	..
1 „	2640	2	57	170	74	615	93	2,105	**105**	**4,880**	..

Velocity and Discharge per Minute in Egg-shaped Sewers, with Water flowing at various depths.

Sewer 4 Feet 6 Inches × 3 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (6¼ Inches.)		One-quarter. (1 Foot 1½ Inch.)		One-half. (2 Feet 3 Inches.		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 100	52·8	314	1230	402	4300	508	14,540	**570**	**33,500**	..
1 „ 132	40	271	1050	350	3740	442	12,650	**497**	**29,250**	85
1 „ 165	32	240	925	314	3360	396	11,320	**444**	**26,130**	125
1 „ 200	26·4	223	860	284	3040	360	10,300	**405**	**23,830**	160
1 „ 264	20	192	740	248	2655	312	8,930	**352**	**20,720**	235
1 „ 330	16	172	664	222	2375	280	8,000	**314**	**18,480**	370
1 „ 440	12	148	572	192	2055	242	6,920	**272**	**16,000**	620
1 „ 528	10	136	525	175	1870	221	6,325	**248**	**14,600**	860
1 „ 660	8	120	463	157	1680	198	5,660	**222**	**13,060**	1350
1 „ 880	6	105	405	136	1455	171	4,700	**192**	**11,300**	2400
1 „ 1056	5	96	372	124	1330	156	4,465	**176**	**10,360**	3550
1 „ 1320	4	86	334	111	1190	140	4,000	**157**	**9,240**	6100
1 „ 1760	3	74	286	96	1030	121	3,460	**136**	**8,000**	..
1 „ 2640	2	60	232	78	840	99	2,834	**111**	**6,530**	..

VELOCITY and DISCHARGE per MINUTE in EGG-SHAPED SEWERS, with Water flowing at various depths.

Sewers 5 Feet × 3 Feet 4 Inches.

Inclination.			Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
			One-eighth (7¼ Inches.)		One-quarter. (1 Foot 3 Inches.)		One-half. (2 Feet 6 Inches.)		Seven-eighths. (Maximum Discharge.)		
			Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
		feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in	100	52·8	322	1554	424	5510	537	19,050	**600**	**43,550**	..
1 „	132	40	280	1342	370	4800	466	16,520	**522**	**37,900**	90
1 „	165	32	252	1205	332	4300	418	14,800	**466**	**33,840**	130
1 „	200	26·4	228	1092	300	3890	380	13,470	**424**	**30,800**	165
1 „	264	20	198	950	260	3370	330	11,700	**368**	**26,800**	250
1 „	330	16	177	848	222	3000	296	10,500	**331**	**24,040**	380
1 „	440	12	154	738	202	2620	255	9,040	**286**	**20,175**	630
1 „	528	10	140	670	185	2400	233	8,260	**261**	**18,950**	865
1 „	660	8	126	603	166	2150	209	7,400	**233**	**16,920**	1,360
1 „	880	6	109	522	143	1855	181	6,420	**202**	**14,670**	2,350
1 „	1056	5	99	475	130	1690	165	5,850	**184**	**13,380**	3,500
1 „	1320	4	89	425	116	1500	148	5,250	**166**	**12,020**	5,700
1 „	1760	3	77	370	101	1310	127	4,500	**143**	**10,390**	..
1 „	2640	2	63	301	83	1075	104	3,700	**116**	**8,466**	..

Velocity and Discharge per Minute in Egg-shaped Sewers, with Water flowing at various depths.

Sewers 6 Feet × 4 Feet.

Inclination.		Depth of Flow in Proportion to Height of Sewer.								Quantity required to give Velocity of 150 Feet per Minute.
		One-eighth. (9 Inches.)		One-quarter. (1 Foot 6 Inches.)		One-half. (3 Feet.)		Seven-eighths. (Maximum Discharge.)		
		Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	Velocity.	Discharge.	
	feet per mile	feet	gallons	feet	gallons	feet	gallons	feet	gallons	gallons
1 in 100	52·8	357	2451	462	8628	583	29,700	**654**	**68,410**	..
1 „ 132	40	313	2148	401	7488	510	25,984	**573**	**59,938**	98
1 „ 165	32	278	1910	360	6720	456	23,230	**512**	**53,560**	140
1 „ 200	26·4	254	1744	327	6106	414	21,093	**466**	**48,746**	175
1 „ 264	20	221	1517	286	5341	360	18,342	**405**	**42,365**	270
1 „ 330	16	198	1359	255	4762	322	16,406	**363**	**37,970**	410
1 „ 440	12	171	1174	221	4127	279	14,215	**314**	**32,800**	640
1 „ 528	10	156	1072	201	3753	255	12,992	**286**	**29,917**	875
1 „ 660	8	139	954	180	3361	228	11,616	**256**	**26,780**	1,380
1 „ 880	6	121	830	156	2913	197	10,037	**242**	**25,314**	2,350
1 „ 1066	5	110	755	143	2670	180	9,171	**202**	**21,130**	3,480
1 „ 1320	4	99	679	127	2372	161	8,203	**181**	**18,933**	5,600
1 „ 1760	3	85	583	110	2054	140	7,130	**156**	**16,318**	11,000
1 „ 2640	2	69	474	90	1681	114	5,800	**128**	**13,389**	..

TABLE VII.—DISCHARGE of PIPES (running full).

NOTE.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	⅜ Inch. (·005 Galls. per Ft.)	½ Inch. (·008 Galls. per Ft.)	¾ inch. (·019 Galls. per Ft.)	1 Inch. (·034 Galls. per Ft.)	1¼ Inch. (·053 Galls. per Ft.)	1½ Inch. (·076 Galls. per Ft.)	2 Inches. (·135 Galls. per Ft.)	2½ Inches. (·212 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 to 1	2·39	4·91	13·52	27·75	48·55	76·66	157·2	274·8
1 „ 2	1·70	3·47	9·56	19·63	34·32	54·23	111·2	194·4
1 „ 3	1·38	2·85	7·86	16·13	28·20	44·54	91·3	159·7
1 „ 4	1·19	2·46	6·76	13·87	24·27	38·33	78·6	137·4
1 „ 5	1·07	2·20	6·05	12·40	21·70	34·28	70·3	122·8
1 „ 6	·97	2·00	5·52	11·33	19·81	31·29	64·2	112·2
1 „ 7	·90	1·85	5·10	10·47	18·32	28·93	59·3	103·7
1 „ 8	·85	1·73	4·78	9·81	17·15	27·09	55·5	97·1
1 „ 9	·80	1·64	4·51	9·25	16·18	25·55	52·4	91·6
1 „ 10	·75	1·55	4·28	8·78	15·36	24·26	49·7	87·0
1 „ 12	·69	1·42	3·91	8·02	14·30	22·16	45·4	79·4
1 „ 14	·64	1·32	3·62	7·44	13·00	20·50	42·1	73·5
1 „ 16	·60	1·23	3·38	6·94	12·14	19·16	39·3	68·7
1 „ 18	·56	1·17	3·19	6·53	11·44	18·10	37·1	64·8
1 „ 20	·53	1·10	3·03	6·21	10·85	17·15	35·2	61·3

Discharge of Pipes (running full).

Note.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	¾ Inch. (·005 Galls. per Ft.)	½ Inch. (·008 Galls. per Ft.)	¾ Inch. (·019 Galls. per Ft.)	1 Inch. (·034 Galls. per Ft.)	1¼ Inch. (·053 Galls. per Ft.)	1½ Inch. (·076 Galls. per Ft.)	2 Inches. (·135 Galls. per Ft.)	2½ Inches. (·212 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 to 25	·48	·98	2·71	5·55	9·70	15·33	31·4	55·0
1 „ 30	·44	·90	2·48	5·08	8·90	14·05	29·3	50·0
1 „ 35	·40	·83	2·28	4·69	8·20	12·95	26·5	46·4
1 „ 40	·38	·78	2·14	4·40	7·70	12·12	24·9	43·4
1 „ 45	·36	·73	2·02	4·14	7·23	11·42	23·4	41·0
1 „ 50	·33	·69	1·92	3·93	6·86	10·80	22·2	38·9
1 „ 60	·31	·64	1·76	3·60	6·30	9·90	20·4	35·6
1 „ 70	·28	·59	1·62	3·32	5·80	9·16	18·8	32·8
1 „ 80	·27	·55	1·50	3·10	5·40	8·60	17·5	30·7
1 „ 100	·24	·49	1·34	2·77	4·86	7·66	15·7	27·5
1 „ 120	·21	·44	1·23	2·52	4·40	6·95	14·3	24·9
1 „ 150	·19	·40	1·11	2·27	3·96	6·26	12·8	22·4
1 „ 200	·17	·35	·96	1·96	3·43	5·42	11·1	19·4
1 „ 250	·15	·31	·85	1·75	3·07	4·85	9·9	17·4
1 „ 300	·14	·29	·79	1·61	2·82	4·45	9·1	16·0

Discharge of Pipes (running full).

Note.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	3 Inches. (·305 Galls. per Ft.)	4 Inches. (·54 Galls. per Ft.)	5 Inches. (·85 Galls. per Ft.)	6 Inches. (1·22 Galls. per Ft.)	7 Inches. (1·66 Galls. per Ft.)	8 Inches. (2·17 Galls. per Ft.)	9 Inches. (2·75 Galls. per Ft.)	10 Inches. (3·39 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 to 5	193	398	695	1097	1613	2253	3020	3933
1 „ 10	137	281	491	776	1140	1592	2138	2780
1 „ 15	112	230	401	633	931	1300	1745	2270
1 „ 20	97	199	347	548	806	1126	1511	1967
1 „ 25	86	178	311	491	721	1007	1352	1759
1 „ 30	79	162	283	448	658	920	1234	1606
1 „ 35	73	150	263	415	610	851	1142	1487
1 „ 40	68	141	246	388	570	796	1069	1391
1 „ 45	64	133	232	366	538	751	1007	1311
1 „ 50	61	126	222	347	510	712	956	1244
1 „ 60	56	115	201	317	466	650	873	1136
1 „ 70	52	106	186	293	431	594	808	1051
1 „ 80	49	99	174	274	403	563	756	983
1 „ 90	46	94	164	258	380	536	712	927
1 „ 100	43	89	155	245	360	503	676	879

Discharge of Pipes (running full).

Note.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	3 Inches. (·305 Galls. per Ft.)	4 Inches. (·54 Galls. per Ft.)	5 Inches. (·85 Galls. per Ft.)	6 Inches. (1·22 Galls. per Ft.)	7 Inches. (1·66 Galls. per Ft.)	8 Inches. (2·17 Galls. per Ft.)	9 Inches. (2·75 Galls. per Ft.)	10 Inches. (3·39 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 „ 125	39	80	139	219	323	450	605	786
1 „ 150	36	73	127	200	296	411	552	718
1 „ 175	33	67	117	183	273	380	510	665
1 „ 200	31	62	109	173	262	352	478	622
1 „ 250	27	56	98	154	227	317	426	554
1 „ 300	25	51	90	142	208	291	390	508
1 „ 350	23	47	83	131	193	270	361	470
1 „ 400	21	44	78	123	180	252	338	440
1 „ 450	20	42	73	116	170	238	319	415
1 „ 500	19	40	69	110	161	225	302	393
1 „ 600	18	36	63	100	147	206	276	360
1 „ 700	17	34	59	93	136	191	256	332
1 „ 800	16	31	55	87	127	178	239	320
1 „ 900	15	29	52	82	120	168	226	293
1 „1000	14	28	49	78	114	159	214	278

Discharge of Pipes (running full).

Note.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	12 Inches. (4·91 Galls. per Ft.)	15 Inches. (7·67 Galls. per Ft.)	18 Inches. (11·04 Galls. per Ft.)	21 Inches. (15 Galls. per Ft.)	24 Inches. (19·6 Galls. per Ft.)	27 Inches. (24·8 Galls. per Ft.)	30 Inches. (30·7 Galls. per Ft.)	36 Inches. (44·2 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 to 20	3,103	5,420	8,551	12,570	17,552	23,360	30,660	48,365
1 „ 25	2,775	4,848	7,648	11,240	15,698	21,070	27,422	43,265
1 „ 30	2,533	4,426	6,982	10,262	14,330	19,235	25,034	39,490
1 „ 40	2,194	3,833	6,047	8,888	12,411	16,660	21,680	34,200
1 „ 50	1,962	3,428	5,408	7,950	11,100	14,900	19,390	30,588
1 „ 60	1,792	3,130	4,937	7,257	10,133	13,600	17,704	27,926
1 „ 70	1,660	2,897	4,571	6,717	9,382	12.593	16,390	25,854
1 „ 80	1,551	2,710	4,276	6,284	8,776	11,943	15,330	24,182
1 „ 90	1,462	2,555	4,032	5,925	8,274	11,105	14,452	22,000
1 „ 100	1,387	2,424	3,824	5,621	7,850	10,535	13,712	21,628
1 „ 125	1,241	2,168	3,420	5,027	7,021	9,423	12,264	19,346
1 „ 150	1,133	1,980	3,123	4,591	6,411	8,605	11,200	17,665
1 „ 175	1,049	1,832	2,890	4,250	5,933	7,964	10,365	16,350
1 „ 200	981	1,714	2,698	3,974	5,538	7,450	9,695	15,294
1 „ 250	874	1,527	2,410	3,542	4,946	6,638	8,640	13,628

Discharge of Pipes (running full).

Note.—The velocity in feet per minute may be ascertained in each case by dividing the discharge by the number of gallons contained in each lineal foot of the pipe as given at the top of the column.

Ratio of Head of Water to Length of Pipe.	Diameter of Pipe.							
	12 Inches. (4·91 Galls. per Ft.)	15 Inches. (7·67 Galls. per Ft.)	18 Inches. 11·04 Galls. per Ft.)	21 Inches. (15 Galls. per Ft.)	24 Inches. (19·6 Galls. per Ft.)	27 Inches. (24·8 Galls. per Ft.)	30 Inches. (30·7 Galls. per Ft.)	36 Inches. (44·2 Galls. per Ft.)
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
1 to 300	801	1,400	2,208	3,245	4,532	6,083	7,916	12,488
1 „ 350	742	1,296	2,044	3,004	4,196	5,567	7,330	11,560
1 „ 400	694	1,212	1,912	2,810	3,925	5,268	6,856	10,814
1 „ 450	654	1,143	1,803	2,650	3,700	4,966	6,464	10,198
1 „ 500	620	1,084	1,710	2,514	3,510	4,712	6,132	9,675
1 „ 600	566	990	1,561	2,295	3,204	4,300	5,597	8,830
1 „ 700	524	916	1,445	2,124	2,971	3,982	5,182	8,174
1 „ 800	490	857	1,352	1,987	2,775	3,725	4,848	7,647
1 „ 900	462	808	1,275	1,873	2,616	3,512	4.570	7.240
1 „ 1000	439	766	1,210	1,777	2,482	3,332	4,336	6,840
1 „ 1250	392	684	1,081	1,590	2,220	2,980	3,878	6,118
1 „ 1500	358	627	987	1,451	2,027	2,720	3,540	5,585
1 „ 2000	310	542	855	1,257	1,755	2,356	3,066	4,836
1 „ 3000	253	443	698	1,026	1,433	1,924	2,503	3,949
1 „ 5000	196	343	541	795	1,110	1,490	1,939	3,059

TABLE VIII.—QUANTITY of SEWAGE due to POPULATION.

Population.	Average Flow during 24 hours.			Maximum Flow, half in 6 hours.			Allowance for Rainfall for Population of 100 per acre, or 435 super. feet of area per inhabitant.		
	At 20 Galls. per Head.	At 30 Galls. per Head.	At 50 Galls. per Head.	At 20 Galls. per Head.	At 30 Galls. per Head.	At 50 Galls. per Head.	At ¼ Inch in 24 Hours.	At ½ Inch in 24 Hours.	At 1 Inch in 24 hours.
	galls. per min.	galls. per min.	galls. per min.	galls per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
500	7	10	17	14	21	35	19·6	39·3	78·7
1,000	14	21	35	28	42	69	39	79	157
2,000	28	42	69	56	83	139	79	157	315
3,000	42	62	104	83	125	208	118	236	472
4,000	56	83	139	111	167	278	157	315	629
5,000	69	104	174	139	208	347	196	393	787
6,000	83	125	208	167	250	417	235	472	944
7,000	97	146	243	194	292	486	275	551	1,101
8,000	111	167	278	222	338	556	314	630	1,258
9,000	125	187	312	250	375	625	353	708	1,416
10,000	139	208	347	278	417	694	393	787	1,573
20,000	278	417	694	555	833	1,389	787	1,573	3,146
30,000	416	625	1,041	833	1,250	2,083	1,179	2,358	4,717
40,000	555	833	1,389	1,110	1,667	2,778	1,573	3,146	6,292
50,000	694	1,042	1,736	1,389	2,083	3,472	1,966	3,932	7,865

Quantity of Sewage due to Population.

Population.	Average Flow during 24 hours.			Maximum Flow, half in 6 hours.			Allowance for Rainfall for Population of 100 per acre, or 435 super. feet of area per inhabitant.		
	At 20 Galls. per Head.	At 30 Galls. per Head.	At 50 Galls. per Head.	At 20 Galls. per Head.	At 30 Galls. per Head.	At 50 Galls. per Head.	At ¼ Inch in 24 Hours.	At ½ Inch in 24 Hours.	At 1 Inch in 24 Hours.
	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls per min.	galls. per min.	galls. per min.	galls. per min.
60,000	833	1,250	2,083	1,666	2,500	4,166	2,358	4,717	9,434
70,000	972	1,458	2,430	1,944	2,916	4,860	2,652	5,504	11,009
80,000	1,110	1,667	2,778	2,220	3,334	5,556	3,146	6,292	12,584
90,000	1,250	1,875	3,125	2,500	3,750	6,250	3,539	7,079	14,157
100,000	1,389	2,083	3,472	2,778	4,166	6,944	3,932	7,865	15,729

250 gallons per inhabited house, being about 44 gallons per head, is the quantity prescribed by Act of Parliament to be provided for in the Lower Thames Valley and Darenth Valley Main Sewerage Districts. This is understood to include some allowance for rainfall.

Rainfall should not be taken on the basis of population, as in the third column, unless *either* the whole area to be provided for is continuously built upon, *or* the separate system is adopted and rain not admitted to the sewers except in close proximity to houses.

In the former case, if the population be greater than is assumed, the figures in the Table must obviously be *divided* by the ratio to 100; thus, for population of 200 per acre divide by 2, for 150 per acre take two-thirds, &c., and similarly for 50 per acre multiply by 2, &c.

On the other hand, if the system to be adopted is that of excluding the rain water, the average area pertaining to each inhabited house must first be ascertained and the number of persons per house; and the figures in the third column may be adopted or will require modification, according as the result arrived at compares with the assumption of 435 super feet to each individual.

TABLE IX.—QUANTITY and DISCHARGE from AREAS due to RAINFALL.

Area.	Quantity equal to 1 Inch of Rain over Surface.	Equivalent Supply Daily throughout the Year.	Quantity running off at following Rates.							
			1 Inch in an hour.	½ Inch in an hour.	¼ Inch in an hour.	⅛ Inch in an hour.	1 Inch in 24 hours.	½ Inch in 24 hours.	¼ Inch in 24 hours.	⅛ Inch in 24 hours.
	gallons	gallons	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
100 sup. feet	52	0·14	0·87	0·43	0·22	0·11	0·036	0·018	0·009	0·005
200 „	104	0·28	1·74	0·87	0·43	0·22	0·072	0·036	0·018	0·009
300 „	156	0·43	2·60	1·30	0·65	0·32	0·108	0·054	0·027	0·013
400 „	208	0·57	3·47	1·74	0·87	0·43	0·144	0·072	0·036	0·018
500 „	260	0·71	4·34	2·17	1·08	0·54	0·181	0·090	0·045	0·022
1,000 „	520	1·4	8·7	4·3	2·2	1·1	0·36	0·18	0·09	0·05
2,000 „	1,040	2·8	17·4	8·7	4·3	2·2	0·72	0·36	0·18	0·09
3,000 „	1,560	4·3	26·0	13·0	6·5	3·2	1·08	0·54	0·27	0·13
4,000 „	2,080	5·7	34·7	17·4	8·7	4·3	1·44	0·72	0·36	0·18
5,000 „	2,600	7·1	43·4	21·7	10·8	5·4	1·81	0·90	0·45	0·22
10,000 „	5,200	14·2	86·8	43·4	21·7	10·8	3·62	1·81	0·90	0·45
1 acre	22,651	62	377	189	94	47	15·7	7·9	3·9	2·0
2 acres	45,302	124	755	377	189	94	31·5	15·7	7·9	3·9
3 „	67,954	186	1,132	566	284	142	47·2	23·6	11·8	5·9
4 „	90,605	248	1,510	755	378	189	63·0	31·5	15·7	7·9
5 „	113,256	310	1,887	944	472	236	78·7	39·3	19·6	9·8

Quantity and Discharge from Areas due to Rainfall.

Area.	Quantity equal to 1 Inch of Rain over Surface.	Equivalent Supply Daily throughout the Year.	Quantity running off at following Rates.							
			1 Inch in an hour.	¾ Inch in an hour.	½ Inch in an hour.	¼ Inch in an hour.	1 Inch in 24 hours.	¾ Inch in 24 hours.	½ Inch in 24 hours.	¼ Inch in 24 hours.
	gallons	gallons	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.	galls. per min.
10 acres	226,512	620	3,775	1,888	944	472	157	79	39	20
20 „	453,025	1,241	7,550	3,775	1,888	944	315	157	79	39
30 „	679,537	1,862	11,326	5,663	2,831	1,415	472	236	118	59
40 „	906,049	2,482	15,101	7,550	3,776	1,888	629	315	157	79
50 „	1,132,561	3,103	18,876	9,438	4,719	2,360	787	393	196	98
100 „	2,265,122	6,206	37,752	18,876	9,438	4,719	1,573	787	393	196
200 „	4,530,245	12,412	75,504	37,752	18,876	9,438	3,146	1,573	787	393
300 „	6,795,367	18,618	113,256	56,628	28,314	14,152	4,717	2,358	1,179	589
400 „	9,060,490	24,823	151,008	75,504	37,752	18,876	6,292	3,145	1,573	787
500 „	11,325,612	31,029	188,760	94,380	47,190	23,595	7,865	3,932	1,966	983
1 square mile	14,496,770	39,717	241,613	120,806	60,403	30,201	10,067	5,033	2,516	1,258

It is estimated that on an average four-fifths of the Rain runs off slated roofs, one-half off streets and paved surfaces; and one-eighth part off the surface of cultivated land, within an hour of falling, whenever the fall is considerable.

Table X.—Annual Rainfall.

(1) Mean Annual Rainfall during thirty years (1850–1879) at forty-six Stations in British Isles.

County.	Place.	Height above Sea.	Mean Annual Rainfall.	County.	Place.	Height above Sea.	Mean Annual Rainfall.
England—		feet	inches	England (*contd.*)—		feet	inches
Kent	Greenwich ..	155	25·2	Cornwall	Bodmin	315	47·7
Sussex	Uckfield	149	30·8	Lancashire	Ormskirk ..	38	35·0
„	Chichester ..	284	33·5	„	Stonyhurst ..	376	46·9
Hertford	Hitchin	238	25·0	„	Bolton, The Fold	286	46·7
„	Berkhampstead	370	29·5	„	Bolton, Belmont	481	55·9
Bucks	High Wycombe	225	24·9	Yorkshire	Leeds	94	22·9
Northampton ..	Northampton ..	310	23·5	„	Redmires ..	1100	40·1
Bedford	Cardington ..	106	23·1	„	Standidge ..	1100	51·6
Norfolk	Norwich	137	25·8	Northumberland	Whittle Dean ..	(?)	25·4
Lincoln	Spalding	20	24·5	Cumberland ..	Keswick	270	58·8
Shropshire	Shiffnal	353	26·5	„ ..	Seathwaite ..	422	138·7
Worcester	Tenbury	200	31·0	Westmoreland ..	Kendal	156	50·0
Devon	Exeter	140	31·1				

Annual Rainfall.

(1) Mean Annual Rainfall during thirty years (1850–1879) at forty-six Stations in British Isles.

County.	Place.	Height above Sea.	Mean Annual Rainfall.	County.	Place.	Height above Sea.	Mean Annual Rainfall.
		feet.	inches			feet	inches
Wales—				Scotland (*contd.*)—			
Carnarvon	Llandudno ..	99	32·80	Forfar	Dundee	50	36·0
Glamorgan	Cardiff	39	44·18	Ross	Cromarty ..	28	24·1
				Inverness	Inverness ..	104	25·1
				,, ...	Barrahead ..	640	31·9
Scotland—							
Edinburgh	Inveresk	30	28·0	Sutherland	Cape Wrath ..	355	38·1
,, ...	Glencorse ..	787	38·3	Caithness	Noss Head ..	127	25·9
Lanark	Bothwell Castle	146	29·5				
Renfrew	Waulk Glen ..	280	47·4				
				Ireland—			
Bute	Pladda	55	38·4	Cork	Cork	30	35·1
Argyle	Lismore	37	41·9	Kilkenny	Woodstock ..	400	40·8
,, ...	Ardnamurchan	82	43·5	King's County ..	Tullamore ..	235	27·8
,, ...	Rhinns of Islay	74	33·2	Armagh	Armagh	208	30·4
,, ...	Mull of Cantire	279	43·2				

Annual Rainfall.

(2) Mean Maximum and Minimum Annual Rainfall during fifty-two years (1830–82) at ten Stations in England.

Place.	Mean Annual Rainfall.	Maximum in one Year.		Minimum in one Year.		Minimum Average of Three Consecutive Years.	
	inches		inches		inches		inches
Greenwich	24·8	(1852)	34·0	(1864)	16·4	(1856–8)	20·1
Chichester	33·6	„	50·9	(1854)	21·8	(1854–6)	27·9
Hemel Hempstead	26·8	„	41·1	(1864)	17·0	(1862–4)	22·4
Oxford	23·4	„	35·5	„	14·8	„	18·8
Tenbury	30·0	„	45·4	(1854)	20·7	(1844–6)	25·4
Exeter	30·3	(1872)	46·0	„	18·1	(1854–6)	21·4
Spalding	25·6	(1880)	37·1	(1874)	16·2	„	20·8
Boston	22·7	„	34·4	(1854)	13·8	(1853–5)	18·7
Bolton	47·4	(1831)	62·3	(1844)	34·6	(1855–7)	41·5
Kendal	51·5	(1872)	69·2	(1855)	34·5	(1854–6)	40·0

Table XI.—Monthly Rainfall.

(1) Observations at Greenwich, 1841 to 1879.

Month.	Mean Fall during Thirty-nine Years.	Maximum Fall in any One Year.	Minimum Fall in any One Year.	Minimum Falls in any Three, Four, and Six consecutive Months.
	inches	inches	inches	
January	2·12	(1877) 4·35	(1861) 0·55	
February	1·44	(1866) 4·03	(1857) 0·30	Minimum in three months:— (April, May, June, 1870), 1·14 in. (Feb., Mar., April, 1863), 1·65 in.
March	1·47	(1851) 4·05	(1852) 0·17	
April	1·66	(1878) 4·31	(1855) 0·09	Minimum in four months:— (Dec., 1873, to Mar., 1874), 2·70 in. (Feb. to Mar., 1863), 2·90 in.
May	2·07	(1865) 4·37	(1844) 0·30	
June	2·05	(1860) 5·80	(1849) 0·30	
July	2·40	(1867) 5·81	(1864) 0·27	Minimum in six months:— (Dec., 1873, to May, 1874), 4·47 in. (Jan. to June, 1870), 5·22 in.
August	2·49	(1878) 5·38	(1849) 0·45	
September	2·25	(1871) 4·12	(1865) 0·16	
October	2·82	(1841) 5·95	(1879) 0·76	
November	2·23	(1852) 6·00	(1867) 0·42	
December	1·76	(1876) 5·76	(1873) 0·31	
Whole year	24·76	(1852) 34·01	(1864) 16·38	

(2) Observations at Glencorse, Edinburgh, 700 feet above sea, 1852 to 1882.

Month.	Mean Fall during Twenty-one Years.	Maximum Fall in any One Year.	Minimum Fall in any One Year.	Minimum Falls in any Three, Four, and Six consecutive Months.
	inches	inches	inches	
January	4·20	(1863) 9·40	(1879) 1·70	
February	3·03	(1868) 6·00	(1874) 1·20	Minimum in three months:— (Feb., Mar., April, 1873), 3·30 in. (Feb., Mar., April, 1865), 3·55 in.
March	2·87	(1876) 6·10	(1863) 0·95	
April	2·58	(1880) 5·00	(1865–73) 0·40	Minimum in four months:— (March to June, 1873), 5·05 in. (May to August, 1864), 6·55 in.
May	2·69	(1865) 6·00	(1871) 0·70	
June	2·67	(1879) 6·20	(1865) 0·40	
July	3·57	(1879) 11·00	(1868) 0·55	Minimum of six months:— (Feb. to July, 1873), 10·30 in. (Apr. to Sept., 1864), 10·50 in.
August	4·04	(1877) 9·60	(1864) 0·40	
September	3·55	(1872) 6·15	(1865) 0·70	
October	4·02	(1874) 9·90	(1866) 1·45	
November	3·63	(1872–5) 5·75	(1867) 0·25	
December	3·78	(1882) 8·45	(1870) 2·40	
Whole year	40 63	(1877) 54·30	(1870) 27·70	

TABLE XII.—DAILY and HOURLY MAXIMUM RAINFALL.

Period.	Greatest Ordinary Heavy Fall (as defined by Meteorological Society, all beyond this being recorded as "Extraordinary").	Extraordinary Falls recorded during the Years 1879, 1880 and 1881.
hours		fall during the year.
	2 inches, where the total fall during the year exceeds 33 inches	5·42 at Sligachan, Skye .. .. 115·41 4·99 at Seathwaite .. .. 130·58 [Falls of 6·41 and 6·70 have been recorded at this Station in previous years.] 4·85 at Bridgend, Glamorgan 121·12 4·17 at Aberdare .. .. .. 98·83 3·91 at Neath .. .. 85·83
24	6 per cent. of the fall during the year, where it does not exceed 33 inches	3·80 at Cambridge, being 12·3 p. c. of 30·96 3·75 at Huntingdon „ 11·8 „ 31·89 3·30 at Upwell „ 11·7 „ 28·14 3·57 at Stockton „ 11·4 „ 31·31 3·54 at Northallerton „ 10·8 „ 32·66 3·20 at Aboyne „ 10·6 „ 30·01
2	·83 inch, or at rate of ·42 per hour	3 inches = 1½ per hour. Rotherham, Sept. 15, 1880.
1¾	·82 inch, or at rate of ·49 per hour	
1½	·78 inch, or at rate of ·52 per hour	1·42 inches = ·94 per hour. Ross, Aug. 23, 1881.
1¼	·75 inch, or at rate of ·60 per hour	3·07 inches = 2·45 per hour! Athlone, June 25, 1880.
1	·70 inch	1·31 inches. Congleton, July 31, 1881.
min. 45	·60 inch, or at rate of ·80 per hour	
30	·50 inch, or at rate of 1 in. per hr.	2·90 inches = 5·80 per hour! Cowbridge, South Wales, July 22, 1880.
25	·44 inch, or at rate of 1·06 in. per hr.	1·18 inches = 2·18 per hour. Llandudno, May 26, 1881.
20	·40 inch, or at rate of 1·20 in. per hr.	1·48 inches = 4·44 per hour! Barnstaple, June 30, 1879.
15	·35 inch, or at rate of 1·40 in. per hr.	
10	·30 inch, or at rate of 1·80 in. per hr.	·41 inch = 2·46 per hour. Darlington, Jan. 11, 1881. ·51 inch = 3·40 per hour. Midmar (Aberdeen), Aug. 23, 1879.
5	·20 inch, or at rate of 2·40 in. per hr.	·31 inch in 5 minutes = 3·72 per hour. Sheffield, Aug. 17, 1879. ·27 inch in 3½ minutes = 4·63 per hour. London, June 24, 1879.

TABLE XIII.—WATER SUPPLY by GRAVITATION—NOTE.—Dimensions of Service Reservoirs and Distributing

Population.	Supply Required at 20 Gallons per Head.		Area of Gathering Ground for 12 Inches Available Rainfall.	Storage Reservoir to Hold Supply for 150 Days.
	Daily.	Equivalent per Minute.		
	gallons	gallons	acres	
500	10,000	7	13½	175 ft. diam. by 10 ft. deep
1,000	20,000	14	27	226 ,, 12 ,,
2,000	40,000	28	53⅓	320 ,, 12 ,,
3,000	60,000	42	80½	391 ,, 12 ,, / 2¾ acres by 12 ,,
5,000	100,000	70	134	3¾ ,, 15 ,,
6,000	120,000	84	161	4½ ,, 15 ,,
8,000	160,000	112	215	6 ,, 15 ,,
10,000	200,000	139	268	7½ ,, 15 ,, / 5½ ,, 20 ,,
20,000	400,000	278	536	15 ,, 15 ,, / 11 ,, 20 ,,
30,000	600,000	417	805	16½ ,, 20 ,,
50,000	1,000,000	694	1340	27½ ,, 20 ,,
60,000	1,200,000	833	1610	33 ,, 20 ,,
80,000	1,600,000	1,111	2145	44 ,, 20 ,,
			sq. miles	
100,000	2,000,000	1,389	4·2	55 ,, 20 ,, / 44 ,, 25 ,,
500,000	10,000,000	6,944	21	220 ,, 25 ,, / 183 ,, 30 ,,
1,000,000	20,000,000	13,889	42	440 ,, 25 ,, / 367 ,, 30 ,,

WORKS for GIVEN POPULATION.

Mains same as for Pumping Works. (See next page.)

Filter Beds to Pass 600 Gallons per Super. Yard in 24 Hours, allowing for one not in use.	Main Conduit to Pass Supply in 24 Hours, flowing continuously.
No. 2, each 15 ft. by 10 ft.	1½ inch, loss of head 1 in 120 2 „ „ 1 „ 400
„ „ 20 „ 15 „	2 „ „ 1 „ 120 3 „ „ 1 „ 1000
No. 3, „ 30 „ 10 „	3 „ „ 1 „ 240 4 „ „ 1 „ 1000
„ „ 30 „ 15 „	4 „ „ 1 „ 450 5 „ „ 1 „ 1200
„ „ 50 „ 15 „	4 „ „ 1 „ 160 6 „ „ 1 „ 1200
„ „ 50 „ 18 „	5 „ „ 1 „ 350 6 „ „ 1 „ 900
„ „ 60 „ 20 „	6 „ „ 1 „ 500 7 „ „ 1 „ 1000
No. 4, „ 50 „ 20 „ or 32 ft. sq.	6 „ „ 1 „ 300 8 „ „ 1 „ 1250
No. 4, each 45 ft. square ..	9 „ „ 1 „ 600 10 „ „ 1 „ 1000
„ „ 55 „ ..	10 „ „ 1 „ 450 12 „ „ 1 „ 1000
„ „ 70 „ ..	12 „ „ 1 „ 400 15 „ „ 1 „ 1200
„ „ 76 „ ..	12 „ „ 1 „ 275 15 „ „ 1 „ 850
„ „ 90 „ ..	15 „ „ 1 „ 480 18 „ „ 1 „ 1200
No. 6 „ 77½ „ ..	18 „ „ 1 „ 750 21 „ „ 1 „ 1700
„ „ 173 „ ..	2½ feet, „ 1 „ 400 3 „ „ 1 „ 1000
„ „ 245 „ ..	3 „ „ 1 „ 250 4 „ „ 1 „ 1000

TABLE XIV.—WATER SUPPLY by PUMPING—

Population.	Supply Required at 20 Gallons per Head.		Hours during which it is proposed to Pump.	Net Horse-power to raise to 100 Feet Elevation.
	Daily.	Equivalent per Minute.		
	gallons	gallons		
500	10,000	7	4	$1\frac{1}{4}$
1,000	20,000	14	6	$1\frac{3}{4}$
2,000	40,000	28	10	2
3,000	60,000	42	10	3
5,000	100,000	70	10	5
6,000	120,000	84	10	6
8,000	160,000	112	10	8
10,000	200,000	139	10	$10\frac{1}{8}$
20,000	400,000	278	18	$11\frac{1}{4}$
30,000	600,000	417	24	$12\frac{3}{3}$
50,000	1,000,000	694	24	21
60,000	1,200,000	833	24	$25\frac{1}{4}$
80,000	1,600,000	1,111	24	$33\frac{1}{2}$
100,000	2,000,000	1,389	24	42
500,000	10,000,000	6,944	24	210
1,000,000	20,000,000	13,889	24	421

WORKS for GIVEN POPULATION.

Dimensions of Single Pump, working 10 Strokes per Minute.		Dimensions of Pumping Main.		Service Reservoir to hold Three Days' Supply.	Main Delivery Pipe to Pass at Rate of One-half in Four Hours.	
Diam	Stroke.	Diam.	Loss of Head.		Diam.	Loss of Head.
in.	ft. in.	in.			in.	
8	2 0	3	1 in 110	22 ft. sq. by 10 ft. deep	3	1 in 400
9	2 0	4	1 „ 450	31 „ 10 „	4	1 „ 450
10	2 0	5	1 „ 500	40 „ 12 „	5	1 „ 350
12	2 1	5	1 „ 240	49 „ 12 „	6	1 „ 380
14	2 6	6	1 „ 220	56½ „ 15 „	8	1 „ 580
15	2 8	7	1 „ 330	62 „ 15 „	8	1 „ 400
16	3 0	8	1 „ 350	71½ „ 15 „	9	1 „ 400
18	3 1	9	1 „ 400	80 „ 15 „	10	1 „ 450
18	3 4½	9	1 „ 335	98 „ 20 „	15	1 „ 850
18	3 9	10	1 „ 450	120 „ 20 „	15	1 „ 440
21	5 0	12	1 „ 400	155 „ 20 „	18	1 „ 340
24	4 3	15	1 „ 850	170 „ 20 „	21	1 „ 500
24	5 8	15	1 „ 475	196 „ 20 „	24	1 „ 570
24	7 0	18	1 „ 770	220 „ 20 „	27	1 „ 650
3·9	10 0	ft. in. 2 6	1 „ 385	438 „ 25 „	ft. in. 4 0	1 „ 500
5·0	11 4	3 0	1 „ 245	620 „ 25 „	6 0	1 „ 880

Table XV.—Analysis of Water.

Results in parts per 100,000. To convert the figures in columns 1 to 6 into grains per gallon (which is a usual measure with these substances), multiply by seven-tenths. Grains per gallon of Hardness (columns 3, 4, and 5) are generally described as "degrees of hardness."

Source or Description of Water.	(1) Total Solid Matter in Solution.	(2) Temporary Hardness.	(3) Permanent Hardness.	(4) Total Hardness.	(5) Chlorine.	(6) Organic Carbon.	(7) Organic Nitrogen.	(8) Ammonia.	(9) Nitrogen in Nitrates.	(10) Free Ammonia by Distillation.	(11) Albuminoid Ammonia by Distillation.
Rain Water (average)	2·9	..	..	0·3	0·2	·070	·015	·029	·003	..	..
Glasgow (Loch Katrine)	3·1	..	..	1·0	0·7	·132	·014	·000	·008	·000	·008
Edinburgh (gathering grounds)	8·9	0·0	4·7	4·7	0·9	·638	·034	·005	·000	·000	·007
Whitehaven (Ennerdale Lake)	2·2	0·0	1·45	1·4	1·0	·042	·017	·000	·000	..	..
Sunderland (deep well in Dolomite)	44·2	0·8	13·9	14·7	4·2	·035	·030	·000	·416	·003	·002
Liverpool (Green Lane Well, New Red Sandstone)	26·4	4·0	9·5	13·5	2·7	·020	·020	·000	·416	..	..
Ditto (Rivington Pike gathering grounds)	8·5	0·1	3·6	3·7	1·5	·243	·031	·004	·000	..	..
Manchester (gathering grounds)	6·2	0·1	3·6	3·7	1·1	·18	·009	·006	·025	·001	·006
St. Helens (deep well in New Red Sandstone)	21·7	5·9	6·8	12·7	1·9	·00	·000	·000	·436	..	..
Oldham (gathering grounds)	12·8	0·9	6·0	6·9	1·3	·166	·014	·011	·011	..	..
Ashton-under-Lyne (gathering grounds)	24·1	3·2	11·0	14·2	1·9	·200	·031	·010	·028	·003	·012
Leicester (gathering grounds)	26·3	15·8	9·0	24·8	1·5	·485	·075	·001	·005	..	..

Birkenhead (deep well in New Red Sandstone) ..	18·8	0·15	9·7	9·8	3·4	·041	·038	·000	·366	·000	·002
Norwich (River Wensum)	30·9	21·3	5·3	26·6	3·1	·432	·080	·014	·036	..	..
Tewkesbury (River Severn)	19·3	0·0	10·0	10·0	3·5	·405	·043	·000	·041	..	..
Chester (River Dee)	16·8	5·0	3·7	10·7	2·0	·219	·043	·000	·000	·000	·007
Bedford (River Ouse)	47·9	13·5	15·0	28·5	2·7	·620	·088	·004	..	..	..
Northampton (deep wells in Lias Limestone) ..	57·8	8·6	1·7	10·3	5·15	·168	·024	·003	·000	..	..
Croydon (deep wells in Chalk)	32·0	12·9	9·1	22·0	..	·400	·070	·001	·551	·001	·001
Tring (deep wells in Chalk)	28·6	22·9	3·3	26·2	1·39	·036	·010	·001	·094	..	..
Ditto, after softening by Clark's process	8·2	0·0	3·2	3·2	1·19	·041	·008	·001	..	..	..
Eastbourne (deep well in Hastings Sand)	43·1	13·8	7·1	20·9	10·0	·058	·010	·004	·130	..	..
London Companies, July to Oct. 1883—											
West Middlesex (Thames)	25·8	..	..	19·2	1·50	·138	·021	·000	·166	·001	·005
Southwark and Vauxhall (Thames)	29·4	..	..	19·9	1·55	·158	·023	·000	·178	·002	·005
New River (River Lea and Wells)	26·7	..	..	19·9	1·55	·073	·018	·000	·212	·002	·003
East London (River Lea)	27·2	..	..	19·6	1·70	·115	·026	·000	·182	·004	·005
Kent (deep wells in Chalk)	40·3	..	..	28·7	2·60	·042	·017	·000	·475	·003	·003
Artesian Well, Trafalgar Square)	83·4	2·9	2·9	5·9	16·5	·050	·012	·070	·000	..	..
Thames at London Bridge	34	..	..	27	1·8	·30	·03	·12	·17	·102	·059
Irwell at Salford	55	..	..	23	9·6	1·17	·33	·74	·71	..	..
Croydon Sewage (raw)	46*	..	..	32	4·2	2·51	1·58	3·00	·00	55·0	3·0
Ditto, after passing Sewage Farm	38	..	..	27	2·7	0·64	0·13	0·13	·375	0·63	0·08
Sea Water	3898	49	748	797	1975	0·28	0·16	·006	·033	..	..

* These figures are exclusive of suspended matter.

TABLE XVI.—QUANTITY of BRICKWORK in CIRCULAR SEWERS, CULVERTS, or WELLS.

NOTE.—The quantity of earth displaced will be the sum of the contents and brickwork added together.

Internal Diameter.		Contents of One Lineal Yard.	Brickwork per Lineal Yard.		Internal Diameter.		Contents of One Lineal Yard.	Brickwork per Lineal Yard.	
			4½ Inches Thick.	9 Inches Thick.				9 Inches Thick.	14 Inches Thick.
ft.	in.	cub. ft.	cub. ft.	cub. ft.	ft.	in.	cub. ft.	cub. ft.	cub. ft.
1	6	5·3	6·6	15·9	6	0	84·8	47·7	75·6
1	9	7·2	7·5	17·7	6	6	99·5	51·2	80·8
2	0	9·4	8·4	19·4	7	0	115·5	54·8	86·1
2	3	11·9	9·3	21·2	7	6	132·5	58·3	91·5
2	6	14·7	10·1	23·0	8	0	150·8	61·8	96·8
2	9	17·8	11·0	24·7	8	6	170·2	65·4	102·1
3	0	21·2	11·9	26·5	9	0	190·9	68·9	107·4
3	3	24·9	12·7	28·3	9	6	212·6	72·4	112·7
3	6	28·9	13·7	30·0	10	0	235·6	76·0	118·0
3	9	33·1	14·6	31·8	11	0	285·1	83·1	128·5
4	0	37·6	15·5	33·6	12	0	339·3	90·0	139·1
4	6	47·7	17·2	37·1	13	0	398·2	97·2	149·8
5	0	58·9	19·0	40·6	14	0	461·8	104·2	160·35
5	6	71·3	20·7	44·2	15	0	530·1	111·3	171·0

TABLE XVII.—QUANTITY of BRICKWORK in EGG-SHAPED SEWERS.

Internal Dimensions.				Contents of One Lineal Yard.	Brickwork per Lineal Yard.		Internal Dimensions.				Contents of One Lineal Yard.	Brickwork per Lineal Yard.	
					4½ In. Thick.	9 In. Thick.						4½ In. Thick.	9 In. Thick.
ft.	in.	ft.	in.	cub. ft.	cub. ft.	cub. ft.	ft.	in.	ft.	in.	cub. ft.	cub. ft.	cub. ft.
2	0	× 1	4	6·0	7·4	16·5	3	6	× 2	4	18·5	11·6	25·5
2	3	× 1	6	8·2	8·1	18·8	3	9	× 2	6	21·2	12·4	26·9
2	6	× 1	8	9·4	8·8	20·1	4	0	× 2	8	24·2	13·0	28·3
2	9	× 1	10	11·4	9·5	21·4	4	6	× 3	0	32·9	14·4	31·1
3	0	× 2	0	13·6	10·2	22·7	5	0	× 3	4	37·7	15·8	34·0
3	3	× 2	2	15·9	10·9	24·0	6	0	× 4	0	54·2	18·8	39·4

In egg-shaped sewers about one-seventh part of the brickwork forms the invert, three-sevenths the top, and three-sevenths the sides. The two former should generally be built with radiating bricks of the radius required in each case.

TABLE XVIII.—WEIGHT of CAST-IRON PIPES.

NOTE.—The weight includes proportion due to sockets, pipes of 2 and 2½ inches diameter being in 6-feet lengths, pipes 3 to 12 inches inclusive in 9-feet lengths, and those of larger size in 12-feet lengths, exclusive of socket.

Internal Diameter of Pipe.	For Pressure not exceeding 150 Feet.		For Pressure not exceeding 300 Feet.		For Pressure not exceeding 500 Feet.	
	Thickness of Metal.	Weight per Yard.	Thickness of Metal.	Weight per Yard.	Thickness of Metal.	Weight per Yard.
inches	inch	cwt. qrs. lbs.	inch	cwt. qrs. lbs.	inch	cwt. qrs. lbs.
2	9/32	0 2 24	5/16	0 0 26	11/32	0 1 0
2½	5/16	0 1 0	11/32	0 1 2	3/8	0 1 6
3	5/16	0 1 5	11/32	0 1 9	3/8	0 1 14
4	11/32	0 1 22	3/8	0 1 26	7/16	0 2 5
5	3/8	0 2 14	7/16	0 2 21	1/4	0 3 4
6	3/8	0 2 21	7/16	0 3 5	1/2	0 3 21
7	7/16	0 3 24	1/2	1 0 12	9/16	1 1 0
8	7/16	1 0 12	1/2	1 1 0	9/16	1 1 21
9	1/2	1 1 12	9/16	1 2 2	5/8	1 2 21
10	1/2	1 2 0	9/16	1 2 21	5/8	1 3 14
12	9/16	2 0 0	5/8	2 0 25	11/16	2 1 21
14	5/8	2 2 18	11/16	2 3 21	3/4	3 0 21
15	5/8	2 3 7	11/16	3 0 10	13/16	3 2 14
16	5/8	3 0 0	3/4	3 2 9	7/8	4 0 21
18	11/16	3 3 0	3/4	4 0 0	15/16	4 3 21
21	11/16	4 1 0	13/16	5 0 0	1	6 1 14
24	3/4	5 1 0	7/8	6 1 0	1 1/8	8 0 0
27	3/4	6 0 0	15/16	7 2 0	1 3/16	9 1 0
30	7/8	7 3 14	1	8 3 21	1¼	11 1 0
36	1	10 2 21	1 1/8	11 2 14	1½	15 3 14

TABLE XIX.—WEIGHT of LEAD PIPES.

NOTE.—Columns 1, 2, and 3 are the pipes usually known as "common," "middling," and "strong" respectively; the figures in parenthesis show the weights per length of the coil according to which they are generally specified.

The "common" are available only for pipes with open ends, the "middling" for very slight pressures, and the "strong" for pressure of about 50 feet.

Column 4 are the weights prescribed by the Metropolis Water Act, 1871, and by the regulations of very many towns, and are available for pressures up to 200 feet or thereabouts.

Column 5 are those prescribed at Norwich and some other towns where the pressure is unusually great.

Internal Diameter of Pipe.	Weight per Yard in Lbs.				
	No. 1.	No. 2.	No. 3.	No. 4.	No. 5.
$\frac{3}{8}$ inch	.. ..	.. ..	.. ..	5	$5\frac{1}{2}$
$\frac{1}{2}$ „	$3\frac{1}{3}$ (16 lbs. to 15 ft.)	$4\frac{2}{5}$ (22 lbs. to 15 ft.)	$5\frac{1}{5}$ (26 lbs. to 15 ft.)	6	7
$\frac{5}{8}$ „	.. ..	.. ..	.. ..	$7\frac{1}{2}$	9
$\frac{3}{4}$ „	$4\frac{4}{5}$ (24 lbs. to 15 ft.)	$5\frac{3}{5}$ (28 lbs. to 15 ft.)	$7\frac{1}{5}$ (36 lbs. to 15 ft.)	9	11
1 „	6 (30 lbs. to 15 ft.)	8 (40 lbs. to 15 ft.)	$9\frac{3}{5}$ (46 lbs. to 15 ft.)	12	16
$1\frac{1}{4}$ „	9 (36 lbs. to 12 ft.)	11 (44 lbs. to 12 ft.)	13 (53 lbs. to 12 ft.)	16	$22\frac{1}{2}$
$1\frac{1}{2}$ „	12 (48 lbs. to 12 ft.)	14 (56 lbs. to 12 ft.)	$17\frac{1}{2}$ (70 lbs. to 12 ft.)	24	33

LONDON: PRINTED BY WILLIAM CLOWES AND SONS, LIMITED, STAMFORD STREET AND CHARING CROSS.

BOOKS RELATING

TO

APPLIED SCIENCE

PUBLISHED BY

E. & F. N. SPON,

LONDON: 125, STRAND.

NEW YORK: 35, MURRAY STREET.

A Pocket-Book for Chemists, Chemical Manufacturers, Metallurgists, Dyers, Distillers, Brewers, Sugar Refiners, Photographers, Students, etc., etc. By THOMAS BAYLEY, Assoc. R.C. Sc. Ireland, Analytical and Consulting Chemist and Assayer. Third edition, with additions, 437 pp., royal 32mo, roan, gilt edges, 5*s.*

SYNOPSIS OF CONTENTS:

Atomic Weights and Factors—Useful Data—Chemical Calculations—Rules for Indirect Analysis—Weights and Measures—Thermometers and Barometers—Chemical Physics—Boiling Points, etc.—Solubility of Substances—Methods of Obtaining Specific Gravity—Conversion of Hydrometers—Strength of Solutions by Specific Gravity—Analysis—Gas Analysis—Water Analysis—Qualitative Analysis and Reactions—Volumetric Analysis—Manipulation—Mineralogy—Assaying—Alcohol—Beer—Sugar—Miscellaneous Technological matter relating to Potash, Soda, Sulphuric Acid, Chlorine, Tar Products, Petroleum, Milk, Tallow, Photography, Prices, Wages, Appendix, etc., etc.

The Mechanician: A Treatise on the Construction and Manipulation of Tools, for the use and instruction of Young Engineers and Scientific Amateurs, comprising the Arts of Blacksmithing and Forging; the Construction and Manufacture of Hand Tools, and the various Methods of Using and Grinding them; the Construction of Machine Tools, and how to work them; Machine Fitting and Erection; description of Hand and Machine Processes; Turning and Screw Cutting; principles of Constructing and details of Making and Erecting Steam Engines, and the various details of setting out work, etc., etc. By CAMERON KNIGHT, Engineer. *Containing* 1147 *illustrations*, and 397 pages of letter-press. Third edition, 4to, cloth, 18*s.*

On Designing Belt Gearing. By E. J. COWLING WELCH, Mem. Inst. Mech. Engineers, Author of 'Designing Valve Gearing.' Fcap. 8vo, sewed, 6*d.*

A Handbook of Formulæ, Tables, and Memoranda, for Architectural Surveyors and others engaged in Building. By J. T. HURST, C.E. Thirteenth edition, royal 32mo, roan, 5*s.*

"It is no disparagement to the many excellent publications we refer to, to say that in our opinion this little pocket-book of Hurst's is the very best of them all, without any exception. It would be useless to attempt a recapitulation of the contents, for it appears to contain almost *everything* that anyone connected with building could require, and, best of all, made up in a compact form for carrying in the pocket, measuring only 5 in. by 3 in., and about ¾ in. thick, in a limp cover. We congratulate the author on the success of his laborious and practically compiled little book, which has received unqualified and deserved praise from every professional person to whom we have shown it."—*The Dublin Builder.*

Tabulated Weights of Angle, Tee, Bulb, Round, Square, and Flat Iron and Steel, and other information for the use of Naval Architects and Shipbuilders. By C. H. JORDAN, M.I.N.A. Fourth edition, 32mo, cloth, 2*s.* 6*d.*

Quantity Surveying. By J. LEANING. With 42 illustrations, crown 8vo, cloth, 9*s.*

CONTENTS:

A complete Explanation of the London Practice.
General Instructions.
Order of Taking Off.
Modes of Measurement of the various Trades.
Use and Waste.
Ventilation and Warming.
Credits, with various Examples of Treatment.
Abbreviations.
Squaring the Dimensions.
Abstracting, with Examples in illustration of each Trade.
Billing.
Examples of Preambles to each Trade.
Form for a Bill of Quantities.
Do. Bill of Credits.
Do. Bill for Alternative Estimate.
Restorations and Repairs, and Form of Bill.
Variations before Acceptance of Tender.
Errors in a Builder's Estimate.
Schedule of Prices.
Form of Schedule of Prices.
Analysis of Schedule of Prices.
Adjustment of Accounts.
Form of a Bill of Variations.
Remarks on Specifications.
Prices and Valuation of Work, with Examples and Remarks upon each Trade.
The Law as it affects Quantity Surveyors, with Law Reports.
Taking Off after the Old Method.
Northern Practice.
The General Statement of the Methods recommended by the Manchester Society of Architects for taking Quantities.
Examples of Collections.
Examples of "Taking Off" in each Trade.
Remarks on the Past and Present Methods of Estimating.

A Practical Treatise on Heat, as applied to the Useful Arts; for the Use of Engineers, Architects, &c. By THOMAS BOX. *With* 14 *plates.* Third edition, crown 8vo, cloth, 12*s.* 6*d.*

A Descriptive Treatise on Mathematical Drawing Instruments: their construction, uses, qualities, selection, preservation, and suggestions for improvements, with hints upon Drawing and Colouring. By W. F. STANLEY, M.R.I. Fifth edition, *with numerous illustrations,* crown 8vo, cloth, 5*s.*

Spons' Architects' and Builders' Pocket-Book of Prices and Memoranda. Edited by W. YOUNG, Architect. Royal 32mo, roan, 4*s.* 6*d.*; or cloth, red edges, 3*s.* 6*d.* *Published annually.* Eleventh edition. *Now ready.*

Long-Span Railway Bridges, comprising Investigations of the Comparative Theoretical and Practical Advantages of the various adopted or proposed Type Systems of Construction, with numerous Formulæ and Tables giving the weight of Iron or Steel required in Bridges from 300 feet to the limiting Spans; to which are added similar Investigations and Tables relating to Short-span Railway Bridges. Second and revised edition. By B. BAKER, Assoc. Inst. C.E. *Plates*, crown 8vo, cloth, 5*s.*

Elementary Theory and Calculation of Iron Bridges and Roofs. By AUGUST RITTER, Ph.D., Professor at the Polytechnic School at Aix-la-Chapelle. Translated from the third German edition, by H. R. SANKEY, Capt. R.E. With 500 *illustrations*, 8vo, cloth, 15*s.*

The Builder's Clerk: a Guide to the Management of a Builder's Business. By THOMAS BALES. Fcap. 8vo, cloth, 1*s.* 6*d.*

The Elementary Principles of Carpentry. By THOMAS TREDGOLD. Revised from the original edition, and partly re-written, by JOHN THOMAS HURST. Contained in 517 pages of letterpress, and *illustrated with* 48 *plates and* 150 *wood engravings.* Third edition, crown 8vo, cloth, 18*s.*

Section I. On the Equality and Distribution of Forces—Section II. Resistance of Timber—Section III. Construction of Floors—Section IV. Construction of Roofs—Section V. Construction of Domes and Cupolas—Section VI. Construction of Partitions—Section VII. Scaffolds, Staging, and Gantries—Section VIII. Construction of Centres for Bridges—Section IX. Coffer-dams, Shoring, and Strutting—Section X. Wooden Bridges and Viaducts—Section XI. Joints, Straps, and other Fastenings—Section XII. Timber.

Our Factories, Workshops, and Warehouses: their Sanitary and Fire-Resisting Arrangements. By B. H. THWAITE, Assoc. Mem. Inst. C.E. *With* 183 *wood engravings*, crown 8vo, cloth, 9*s.*

Gold: Its Occurrence and Extraction, embracing the Geographical and Geological Distribution and the Mineralogical Characters of Gold-bearing rocks; the peculiar features and modes of working Shallow Placers, Rivers, and Deep Leads; Hydraulicing; the Reduction and Separation of Auriferous Quartz; the treatment of complex Auriferous ores containing other metals; a Bibliography of the subject and a Glossary of Technical and Foreign Terms. By ALFRED G. LOCK, F.R.G.S. *With numerous illustrations and maps*, 1250 pp., super-royal 8vo, cloth, 2*l.* 12*s.* 6*d.*

A Practical Treatise on Coal Mining. By GEORGE G. ANDRÉ, F.G.S., Assoc. Inst. C.E., Member of the Society of Engineers. *With 82 lithographic plates.* 2 vols., royal 4to, cloth, 3*l.* 12*s.*

Iron Roofs: Examples of Design, Description. *Illustrated with 64 Working Drawings of Executed Roofs.* By ARTHUR T. WALMISLEY, Assoc. Mem. Inst. C.E. Imp. 4to, half-morocco, £2 12*s.* 6*d.*

A History of Electric Telegraphy, to the Year 1837. Chiefly compiled from Original Sources, and hitherto Unpublished Documents, by J. J. FAHIE, Mem. Soc. of Tel. Engineers, and of the International Society of Electricians, Paris. Crown 8vo, cloth, 9*s.*

Spons' Information for Colonial Engineers. Edited by J. T. HURST. Demy 8vo, sewed.

No. 1, Ceylon. By ABRAHAM DEANE, C.E. 2*s.* 6*d.*

CONTENTS:

Introductory Remarks—Natural Productions—Architecture and Engineering—Topography, Trade, and Natural History—Principal Stations—Weights and Measures, etc., etc.

No. 2. Southern Africa, including the Cape Colony, Natal, and the Dutch Republics. By HENRY HALL, F.R.G.S., F.R.C.I. With Map. 3*s.* 6*d.*

CONTENTS:

General Description of South Africa—Physical Geography with reference to Engineering Operations—Notes on Labour and Material in Cape Colony—Geological Notes on Rock Formation in South Africa—Engineering Instruments for Use in South Africa—Principal Public Works in Cape Colony: Railways, Mountain Roads and Passes, Harbour Works, Bridges, Gas Works, Irrigation and Water Supply, Lighthouses, Drainage and Sanitary Engineering, Public Buildings, Mines—Table of Woods in South Africa—Animals used for Draught Purposes—Statistical Notes—Table of Distances—Rates of Carriage, etc.

No. 3. India. By F. C. DANVERS, Assoc. Inst. C.E. With Map. 4*s.* 6*d.*

CONTENTS:

Physical Geography of India—Building Materials—Roads—Railways—Bridges—Irrigation—River Works—Harbours—Lighthouse Buildings—Native Labour—The Principal Trees of India—Money—Weights and Measures—Glossary of Indian Terms, etc.

A Practical Treatise on Casting and Founding, including descriptions of the modern machinery employed in the art. By N. E. SPRETSON, Engineer. Third edition, with 82 *plates* drawn to scale, 412 pp., demy 8vo, cloth, 18*s.*

Steam Heating for Buildings; or, Hints to Steam Fitters, being a description of Steam Heating Apparatus for Warming and Ventilating Private Houses and Large Buildings, with remarks on Steam, Water, and Air in their relation to Heating. By W. J. BALDWIN. *With many illustrations.* Fourth edition, crown 8vo, cloth, 10*s.* 6*d.*

The Depreciation of Factories and their Valuation. By EWING MATHESON, M. Inst. C.E. 8vo, cloth, 6*s.*

A Handbook of Electrical Testing. By H. R. KEMPE, M.S.T.E. Third edition, revised and enlarged, crown 8vo, cloth, 15*s.*

Gas Works: their Arrangement, Construction, Plant, and Machinery. By F. COLYER, M. Inst. C.E. *With* 31 *folding plates*, 8vo, cloth, 24*s.*

The Clerk of Works: a Vade-Mecum for all engaged in the Superintendence of Building Operations. By G. G. HOSKINS, F.R.I.B.A. Third edition, fcap. 8vo, cloth, 1*s.* 6*d.*

American Foundry Practice: Treating of Loam, Dry Sand, and Green Sand Moulding, and containing a Practical Treatise upon the Management of Cupolas, and the Melting of Iron. By T. D. WEST, Practical Iron Moulder and Foundry Foreman. Second edition, *with numerous illustrations*, crown 8vo, cloth, 10*s.* 6*d.*

The Maintenance of Macadamised Roads. By T. CODRINGTON, M.I.C.E, F.G.S., General Superintendent of County Roads for South Wales. 8vo, cloth, 6*s.*

Hydraulic Steam and Hand Power Lifting and Pressing Machinery. By FREDERICK COLYER, M. Inst. C.E., M. Inst. M.E. *With* 73 *plates*, 8vo, cloth, 18*s.*

Pumps and Pumping Machinery. By F. COLYER, M.I.C.E., M.I.M.E. *With* 23 *folding plates*, 8vo, cloth, 12*s.* 6*d.*

The Municipal and Sanitary Engineer's Handbook. By H. PERCY BOULNOIS, Mem. Inst. C.E., Borough Engineer, Portsmouth. *With numerous illustrations*, demy 8vo, cloth, 12*s.* 6*d.*

CONTENTS:

The Appointment and Duties of the Town Surveyor—Traffic—Macadamised Roadways—Steam Rolling—Road Metal and Breaking—Pitched Pavements—Asphalte—Wood Pavements—Footpaths—Kerbs and Gutters—Street Naming and Numbering—Street Lighting—Sewerage—Ventilation of Sewers—Disposal of Sewage—House Drainage—Disinfection—Gas and Water Companies, &c., Breaking up Streets—Improvement of Private Streets—Borrowing Powers—Artizans' and Labourers' Dwellings—Public Conveniences—Scavenging, including Street Cleansing—Watering and the Removing of Snow—Planting Street Trees—Deposit of Plans—Dangerous Buildings—Hoardings—Obstructions—Improving Street Lines—Cellar Openings—Public Pleasure Grounds—Cemeteries—Mortuaries—Cattle and Ordinary Markets—Public Slaughter-houses, etc.—Giving numerous Forms of Notices, Specifications, and General Information upon these and other subjects of great importance to Municipal Engineers and others engaged in Sanitary Work.

Tables of the Principal Speeds occurring in Mechanical Engineering, expressed in metres in a second. By P. KEERAYEFF, Chief Mechanic of the Obouchoff Steel Works, St. Petersburg; translated by SERGIUS KERN, M.E. Fcap. 8vo, sewed, 6*d.*

A Treatise on the Origin, Progress, Prevention, and Cure of Dry Rot in Timber; with Remarks on the Means of Preserving Wood from Destruction by Sea-Worms, Beetles, Ants, etc. By THOMAS ALLEN BRITTON, late Surveyor to the Metropolitan Board of Works, etc., etc. *With* 10 *plates*, crown 8vo, cloth, 7*s.* 6*d.*

Metrical Tables. By G. L. MOLESWORTH, M.I.C.E. 32mo, cloth, 1*s.* 6*d.*

CONTENTS.

General—Linear Measures—Square Measures—Cubic Measures—Measures of Capacity—Weights—Combinations—Thermometers.

Elements of Construction for Electro-Magnets. By Count TH. DU MONCEL, Mem. de l'Institut de France. Translated from the French by C. J. WHARTON. Crown 8vo, cloth, 4*s.* 6*d.*

Electro-Telegraphy. By FREDERICK S. BEECHEY, Telegraph Engineer. A Book for Beginners. *Illustrated.* Fcap. 8vo, sewed, 6*d.*

Handrailing: by the Square Cut. By JOHN JONES, Staircase Builder. Fourth edition, *with seven plates*, 8vo, cloth, 3*s.* 6*d.*

Handrailing: by the Square Cut. By JOHN JONES, Staircase Builder. Part Second, *with eight plates*, 8vo, cloth, 3*s.* 6*d.*

Practical Electrical Units Popularly Explained, with *numerous illustrations* and Remarks. By JAMES SWINBURNE, late of J. W. Swan and Co., Paris, late of Brush-Swan Electric Light Company, U.S.A. 18mo, cloth, 1*s.* 6*d.*

Philipp Reis, Inventor of the Telephone: A Biographical Sketch. With Documentary Testimony, Translations of the Original Papers of the Inventor, &c. By SILVANUS P. THOMPSON, B.A., Dr. Sc., Professor of Experimental Physics in University College, Bristol. *With illustrations*, 8vo, cloth, 7*s.* 6*d.*

A Treatise on the Use of Belting for the Transmission of Power. By J. H. COOPER. Second edition, *illustrated*, 8vo, cloth, 15*s.*

A Pocket-Book of Useful Formulæ and Memoranda for Civil and Mechanical Engineers. By GUILFORD L. MOLESWORTH, Mem. Inst. C.E., Consulting Engineer to the Government of India for State Railways. *With numerous illustrations*, 744 pp., Twenty-first edition, revised and enlarged, 32mo, roan, 6*s*.

SYNOPSIS OF CONTENTS:

Surveying, Levelling, etc.—Strength and Weight of Materials—Earthwork, Brickwork, Masonry, Arches, etc.—Struts, Columns, Beams, and Trusses—Flooring, Roofing, and Roof Trusses—Girders, Bridges, etc.—Railways and Roads—Hydraulic Formulæ—Canals, Sewers, Waterworks, Docks—Irrigation and Breakwaters—Gas, Ventilation, and Warming—Heat, Light, Colour, and Sound—Gravity: Centres, Forces, and Powers—Millwork, Teeth of Wheels, Shafting, etc.—Workshop Recipes—Sundry Machinery—Animal Power—Steam and the Steam Engine—Water-power, Water-wheels, Turbines, etc.—Wind and Windmills—Steam Navigation, Ship Building, Tonnage, etc.—Gunnery, Projectiles, etc.—Weights, Measures, and Money—Trigonometry, Conic Sections, and Curves—Telegraphy—Mensuration—Tables of Areas and Circumference, and Arcs of Circles—Logarithms, Square and Cube Roots, Powers—Reciprocals, etc.—Useful Numbers—Differential and Integral Calculus—Algebraic Signs—Telegraphic Construction and Formulæ.

Spons' Tables and Memoranda for Engineers; selected and arranged by J. T. HURST, C.E., Author of 'Architectural Surveyors' Handbook,' 'Hurst's Tredgold's Carpentry,' etc. Fifth edition, 64mo, roan, gilt edges, 1*s*.; or in cloth case, 1*s*. 6*d*.

This work is printed in a pearl type, and is so small, measuring only 2¼ in. by 1⅛ in. by ¼ in. thick, that it may be easily carried in the waistcoat pocket.

"It is certainly an extremely rare thing for a reviewer to be called upon to notice a volume measuring but 2¼ in. by 1⅛ in., yet these dimensions faithfully represent the size of the handy little book before us. The volume—which contains 118 printed pages, besides a few blank pages for memoranda—is, in fact, a true pocket-book, adapted for being carried in the waistcoat pocket, and containing a far greater amount and variety of information than most people would imagine could be compressed into so small a space. . . . . The little volume has been compiled with considerable care and judgment, and we can cordially recommend it to our readers as a useful little pocket companion."—*Engineering.*

A Practical Treatise on Natural and Artificial Concrete, its Varieties and Constructive Adaptations. By HENRY REID, Author of the 'Science and Art of the Manufacture of Portland Cement.' New Edition, *with* 59 *woodcuts and* 5 *plates*, 8vo, cloth, 15*s*.

Hydrodynamics: Treatise relative to the Testing of Water-Wheels and Machinery, with various other matters pertaining to Hydrodynamics. By JAMES EMERSON. *With numerous illustrations*, 360 pp. Third edition, crown 8vo, cloth, 4*s*. 6*d*.

Electricity as a Motive Power. By Count TH. DU MONCEL, Membre de l'Institut de France, and FRANK GERALDY, Ingénieur des Ponts et Chaussées. Translated and Edited, with Additions, by C. J. WHARTON, Assoc. Soc. Tel. Eng. and Elec. *With* 113 *engravings and diagrams*, crown 8vo, cloth, 7*s*. 6*d*.

Hints on Architectural Draughtsmanship. By G. W. TUXFORD HALLATT. Fcap. 8vo, cloth, 1*s*. 6*d*.

Treatise on Valve-Gears, with special consideration of the Link-Motions of Locomotive Engines. By Dr. GUSTAV ZEUNER, Professor of Applied Mechanics at the Confederated Polytechnikum of Zurich. Translated from the Fourth German Edition, by Professor J. F. KLEIN, Lehigh University, Bethlehem, Pa. *Illustrated*, 8vo, cloth, 12*s.* 6*d.*

The French-Polisher's Manual. By a French-Polisher; containing Timber Staining, Washing, Matching, Improving, Painting, Imitations, Directions for Staining, Sizing, Embodying, Smoothing, Spirit Varnishing, French-Polishing, Directions for Re-polishing. Third edition, royal 32mo, sewed, 6*d.*

Hops, their Cultivation, Commerce, and Uses in various Countries. By P. L. SIMMONDS. Crown 8vo, cloth, 4*s.* 6*d.*

A Practical Treatise on the Manufacture and Distribution of Coal Gas. By WILLIAM RICHARDS. Demy 4to, with *numerous wood engravings and* 29 *plates*, cloth, 28*s.*

SYNOPSIS OF CONTENTS:

Introduction—History of Gas Lighting—Chemistry of Gas Manufacture, by Lewis Thompson, Esq., M.R.C.S.—Coal, with Analyses, by J. Paterson, Lewis Thompson, and G. R. Hislop, Esqrs.—Retorts, Iron and Clay—Retort Setting—Hydraulic Main—Condensers—Exhausters—Washers and Scrubbers—Purifiers—Purification—History of Gas Holder—Tanks, Brick and Stone, Composite, Concrete, Cast-iron, Compound Annular Wrought-iron—Specifications—Gas Holders—Station Meter—Governor—Distribution—Mains—Gas Mathematics, or Formulæ for the Distribution of Gas, by Lewis Thompson, Esq.—Services—Consumers' Meters—Regulators—Burners—Fittings—Photometer—Carburization of Gas—Air Gas and Water Gas—Composition of Coal Gas, by Lewis Thompson, Esq.—Analyses of Gas—Influence of Atmospheric Pressure and Temperature on Gas—Residual Products—Appendix—Description of Retort Settings, Buildings, etc., etc.

Practical Geometry, Perspective, and Engineering Drawing; a Course of Descriptive Geometry adapted to the Requirements of the Engineering Draughtsman, including the determination of cast shadows and Isometric Projection, each chapter being followed by numerous examples; to which are added rules for Shading, Shade-lining, etc., together with practical instructions as to the Lining, Colouring, Printing, and general treatment of Engineering Drawings, with a chapter on drawing Instruments. By GEORGE S. CLARKE, Capt. R.E. Second edition, *with* 21 *plates*. 2 vols., cloth, 10*s.* 6*d.*

The Elements of Graphic Statics. By Professor KARL VON OTT, translated from the German by G. S. CLARKE, Capt. R.E., Instructor in Mechanical Drawing, Royal Indian Engineering College. *With* 93 *illustrations*, crown 8vo, cloth, 5*s.*

The Principles of Graphic Statics. By GEORGE SYDENHAM CLARKE, Capt. Royal Engineers. *With* 112 *illustrations.* 4to, cloth, 12*s.* 6*d.*

Dynamo-Electric Machinery: A Manual for Students of Electro-technics. By SILVANUS P. THOMPSON, B.A., D.Sc., Professor of Experimental Physics in University College, Bristol, etc., etc. *Illustrated*, 8vo, cloth, 12*s.* 6*d.*

The New Formula for Mean Velocity of Discharge of Rivers and Canals. By W. R. KUTTER. Translated from articles in the 'Cultur-Ingénieur,' by LOWIS D'A. JACKSON, Assoc. Inst. C.E. 8vo, cloth, 12*s.* 6*d.*

Practical Hydraulics; a Series of Rules and Tables for the use of Engineers, etc., etc. By THOMAS BOX. Fifth edition, *numerous plates*, post 8vo, cloth, 5*s.*

A Practical Treatise on the Construction of Horizontal and Vertical Waterwheels, specially designed for the use of operative mechanics. By WILLIAM CULLEN, Millwright and Engineer. *With* 11 *plates.* Second edition, revised and enlarged, small 4to, cloth, 12*s.* 6*d.*

Tin: Describing the Chief Methods of Mining, Dressing and Smelting it abroad; with Notes upon Arsenic, Bismuth and Wolfram. By ARTHUR G. CHARLETON, Mem. American Inst. of Mining Engineers. *With plates*, 8vo, cloth, 12*s.* 6*d.*

Perspective, Explained and Illustrated. By G. S. CLARKE, Capt. R.E. *With illustrations*, 8vo, cloth, 3*s.* 6*d.*

The Essential Elements of Practical Mechanics; based on the Principle of Work, designed for Engineering Students. By OLIVER BYRNE, formerly Professor of Mathematics, College for Civil Engineers. Third edition, *with* 148 *wood engravings*, post 8vo, cloth, 7*s.* 6*d.*

CONTENTS:

Chap. 1. How Work is Measured by a Unit, both with and without reference to a Unit of Time—Chap. 2. The Work of Living Agents, the Influence of Friction, and introduces one of the most beautiful Laws of Motion—Chap. 3. The principles expounded in the first and second chapters are applied to the Motion of Bodies—Chap. 4. The Transmission of Work by simple Machines—Chap. 5. Useful Propositions and Rules.

The Practical Millwright and Engineer's Ready Reckoner; or Tables for finding the diameter and power of cog-wheels, diameter, weight, and power of shafts, diameter and strength of bolts, etc. By THOMAS DIXON. Fourth edition, 12mo, cloth, 3*s.*

Breweries and Maltings: their Arrangement, Construction, Machinery, and Plant. By G. SCAMELL, F.R.I.B.A. Second edition, revised, enlarged, and partly rewritten. By F. COLYER, M.I.C.E., M.I.M.E. *With* 20 *plates*, 8vo, cloth, 18*s.*

A Practical Treatise on the Manufacture of Starch, Glucose, Starch-Sugar, and Dextrine, based on the German of L. Von Wagner, Professor in the Royal Technical School, Buda Pesth, and other authorities. By JULIUS FRANKEL; edited by ROBERT HUTTER, proprietor of the Philadelphia Starch Works. *With* 58 *illustrations*, 344 pp., 8vo, cloth, 18*s.*

A Practical Treatise on Mill-gearing, Wheels, Shafts, Riggers, etc.; for the use of Engineers. By THOMAS BOX. Third edition, *with* 11 *plates*. Crown 8vo, cloth, 7*s*. 6*d*.

Mining Machinery: a Descriptive Treatise on the Machinery, Tools, and other Appliances used in Mining. By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E., Mem. of the Society of Engineers. Royal 4to, uniform with the Author's Treatise on Coal Mining, containing 182 *plates*, accurately drawn to scale, with descriptive text, in 2 vols., cloth, 3*l*. 12*s*.

CONTENTS:

Machinery for Prospecting, Excavating, Hauling, and Hoisting—Ventilation—Pumping—Treatment of Mineral Products, including Gold and Silver, Copper, Tin, and Lead, Iron, Coal, Sulphur, China Clay, Brick Earth, etc.

Tables for Setting out Curves for Railways, Canals, Roads, etc., varying from a radius of five chains to three miles. By A. KENNEDY and R. W. HACKWOOD. *Illustrated*, 32mo, cloth, 2*s*. 6*d*.

The Science and Art of the Manufacture of Portland Cement, with observations on some of its constructive applications. *With* 66 *illustrations*. By HENRY REID, C.E., Author of 'A Practical Treatise on Concrete,' etc., etc. 8vo, cloth, 18*s*.

The Draughtsman's Handbook of Plan and Map Drawing; including instructions for the preparation of Engineering, Architectural, and Mechanical Drawings. *With numerous illustrations in the text, and* 33 *plates* (15 *printed in colours*). By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E. 4to, cloth, 9*s*.

CONTENTS:

The Drawing Office and its Furnishings—Geometrical Problems—Lines, Dots, and their Combinations—Colours, Shading, Lettering, Bordering, and North Points—Scales—Plotting—Civil Engineers' and Surveyors' Plans—Map Drawing—Mechanical and Architectural Drawing—Copying and Reducing Trigonometrical Formulæ, etc., etc.

The Boiler-maker's and Iron Ship-builder's Companion, comprising a series of original and carefully calculated tables, of the utmost utility to persons interested in the iron trades. By JAMES FODEN, author of 'Mechanical Tables,' etc. Second edition revised, *with illustrations*, crown 8vo, cloth, 5*s*.

Rock Blasting: a Practical Treatise on the means employed in Blasting Rocks for Industrial Purposes. By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E. *With* 56 *illustrations and* 12 *plates*, 8vo, cloth, 10*s*. 6*d*.

Painting and Painters' Manual: a Book of Facts for Painters and those who Use or Deal in Paint Materials. By C. L. CONDIT and J. SCHELLER. *Illustrated*, 8vo, cloth, 10*s*. 6*d*.

A Treatise on Ropemaking as practised in public and private Rope-yards, with a Description of the Manufacture, Rules, Tables of Weights, etc., adapted to the Trade, Shipping, Mining, Railways, Builders, etc. By R. CHAPMAN, formerly foreman to Messrs. Huddart and Co., Limehouse, and late Master Ropemaker to H.M. Dockyard, Deptford. Second edition, 12mo, cloth, 3*s.*

Laxton's Builders' and Contractors' Tables; for the use of Engineers, Architects, Surveyors, Builders, Land Agents, and others. Bricklayer, containing 22 tables, with nearly 30,000 calculations. 4to, cloth, 5*s.*

Laxton's Builders' and Contractors' Tables. Excavator, Earth, Land, Water, and Gas, containing 53 tables, with nearly 24,000 calculations. 4to, cloth, 5*s.*

Sanitary Engineering: a Guide to the Construction of Works of Sewerage and House Drainage, with Tables for facilitating the calculations of the Engineer. By BALDWIN LATHAM, C.E., M. Inst. C.E., F.G.S., F.M.S., Past-President of the Society of Engineers. Second edition, *with numerous plates and woodcuts*, 8vo, cloth, 1*l.* 10*s.*

Screw Cutting Tables for Engineers and Machinists, giving the values of the different trains of Wheels required to produce Screws of any pitch, calculated by Lord Lindsay, M.P., F.R.S., F.R.A.S., etc. Cloth, oblong, 2*s.*

Screw Cutting Tables, for the use of Mechanical Engineers, showing the proper arrangement of Wheels for cutting the Threads of Screws of any required pitch, with a Table for making the Universal Gas-pipe Threads and Taps. By W. A. MARTIN, Engineer. Second edition, oblong, cloth, 1*s.*, or sewed, 6*d.*

A Treatise on a Practical Method of Designing Slide-Valve Gears by Simple Geometrical Construction, based upon the principles enunciated in Euclid's Elements, and comprising the various forms of Plain Slide-Valve and Expansion Gearing; together with Stephenson's, Gooch's, and Allan's Link-Motions, as applied either to reversing or to variable expansion combinations. By EDWARD J. COWLING WELCH, Memb. Inst. Mechanical Engineers. Crown 8vo, cloth, 6*s.*

Cleaning and Scouring: a Manual for Dyers, Laundresses, and for Domestic Use. By S. CHRISTOPHER. 18mo, sewed, 6*d.*

A Handbook of House Sanitation; for the use of all persons seeking a Healthy Home. A reprint of those portions of Mr. Bailey-Denton's Lectures on Sanitary Engineering, given before the School of Military Engineering, which related to the "Dwelling," enlarged and revised by his Son, E. F. BAILEY-DENTON, C.E., B.A. *With* 140 *illustrations*, 8vo, cloth, 8*s.* 6*d.*

A Glossary of Terms used in Coal Mining. By WILLIAM STUKELEY GRESLEY, Assoc. Mem. Inst. C.E., F.G.S., Member of the North of England Institute of Mining Engineers. *Illustrated with numerous woodcuts and diagrams*, crown 8vo, cloth, 5*s*.

A Pocket-Book for Boiler Makers and Steam Users, comprising a variety of useful information for Employer and Workman, Government Inspectors, Board of Trade Surveyors, Engineers in charge of Works and Slips, Foremen of Manufactories, and the general Steam-using Public. By MAURICE JOHN SEXTON. Second edition, royal 32mo, roan, gilt edges, 5*s*.

The Strains upon Bridge Girders and Roof Trusses, including the Warren, Lattice, Trellis, Bowstring, and other Forms of Girders, the Curved Roof, and Simple and Compound Trusses. By THOS. CARGILL, C.E.B.A.T., C.D., Assoc. Inst. C.E., Member of the Society of Engineers. *With* 64 *illustrations, drawn and worked out to scale*, 8vo, cloth, 12*s*. 6*d*.

A Practical Treatise on the Steam Engine, containing Plans and Arrangements of Details for Fixed Steam Engines, with Essays on the Principles involved in Design and Construction. By ARTHUR RIGG, Engineer, Member of the Society of Engineers and of the Royal Institution of Great Britain. Demy 4to, *copiously illustrated with woodcuts and* 96 *plates*, in one Volume, half-bound morocco, 2*l*. 2*s*.; or cheaper edition, cloth, 25*s*.

This work is not, in any sense, an elementary treatise, or history of the steam engine, but is intended to describe examples of Fixed Steam Engines without entering into the wide domain of locomotive or marine practice. To this end illustrations will be given of the most recent arrangements of Horizontal, Vertical, Beam, Pumping, Winding, Portable, Semi-portable, Corliss, Allen, Compound, and other similar Engines, by the most eminent Firms in Great Britain and America. The laws relating to the action and precautions to be observed in the construction of the various details, such as Cylinders, Pistons, Piston-rods, Connecting-rods, Cross-heads, Motion-blocks, Eccentrics, Simple, Expansion, Balanced, and Equilibrium Slide-valves, and Valve-gearing will be minutely dealt with. In this connection will be found articles upon the Velocity of Reciprocating Parts and the Mode of Applying the Indicator, Heat and Expansion of Steam Governors, and the like. It is the writer's desire to draw illustrations from every possible source, and give only those rules that present practice deems correct.

Barlow's Tables of Squares, Cubes, Square Roots, Cube Roots, Reciprocals of all Integer Numbers up to 10,000. Post 8vo, cloth, 6*s*.

Camus (M.) Treatise on the Teeth of Wheels, demonstrating the best forms which can be given to them for the purposes of Machinery, such as Mill-work and Clock-work, and the art of finding their numbers. Translated from the French, with details of the present practice of Millwrights, Engine Makers, and other Machinists, by ISAAC HAWKINS. Third edition, *with* 18 *plates*, 8vo, cloth, 5*s*.

A Practical Treatise on the Science of Land and Engineering, Surveying, Levelling, Estimating Quantities, etc., with a general description of the several Instruments required for Surveying, Levelling, Plotting, etc. By H. S. MERRETT. Third edition, 41 *plates with illustrations and tables*, royal 8vo, cloth, 12*s.* 6*d.*

PRINCIPAL CONTENTS:

Part 1. Introduction and the Principles of Geometry. Part 2. Land Surveying; comprising General Observations—The Chain—Offsets Surveying by the Chain only—Surveying Hilly Ground—To Survey an Estate or Parish by the Chain only—Surveying with the Theodolite—Mining and Town Surveying—Railroad Surveying—Mapping—Division and Laying out of Land—Observations on Enclosures—Plane Trigonometry. Part 3. Levelling—Simple and Compound Levelling—The Level Book—Parliamentary Plan and Section—Levelling with a Theodolite—Gradients—Wooden Curves—To Lay out a Railway Curve—Setting out Widths. Part 4. Calculating Quantities generally for Estimates—Cuttings and Embankments—Tunnels—Brickwork—Ironwork—Timber Measuring. Part 5. Description and Use of Instruments in Surveying and Plotting—The Improved Dumpy Level—Troughton's Level—The Prismatic Compass—Proportional Compass—Box Sextant—Vernier—Pantagraph—Merrett's Improved Quadrant—Improved Computation Scale—The Diagonal Scale—Straight Edge and Sector. Part 6. Logarithms of Numbers—Logarithmic Sines and Co-Sines, Tangents and Co-Tangents—Natural Sines and Co-Sines—Tables for Earthwork, for Setting out Curves, and for various Calculations, etc., etc., etc.

Saws: the History, Development, Action, Classification, and Comparison of Saws of all kinds. By ROBERT GRIMSHAW. *With* 220 *illustrations*, 4to, cloth, 12*s.* 6*d.*

A Supplement to the above; containing additional practical matter, more especially relating to the forms of Saw Teeth for special material and conditions, and to the behaviour of Saws under particular conditions. *With* 120 *illustrations*, cloth, 9*s.*

A Guide for the Electric Testing of Telegraph Cables. By Capt. V. HOSKIÆR, Royal Danish Engineers. *With illustrations*, second edition, crown 8vo, cloth, 4*s.* 6*d.*

Laying and Repairing Electric Telegraph Cables. By Capt. V. HOSKIÆR, Royal Danish Engineers. Crown 8vo, cloth, 3*s.* 6*d.*

A Pocket-Book of Practical Rules for the Proportions of Modern Engines and Boilers for Land and Marine purposes. By N. P. BURGH. Seventh edition, royal 32mo, roan, 4*s.* 6*d.*

The Assayer's Manual: an Abridged Treatise on the Docimastic Examination of Ores and Furnace and other Artificial Products. By BRUNO KERL. Translated by W. T. BRANNT. *With* 65 *illustrations*, 8vo, cloth, 12*s.* 6*d.*

The Steam Engine considered as a Heat Engine: a Treatise on the Theory of the Steam Engine, illustrated by Diagrams, Tables, and Examples from Practice. By JAS. H. COTTERILL, M.A., F.R.S., Professor of Applied Mechanics in the Royal Naval College. 8vo, cloth, 12*s.* 6*d.*

Electricity: its Theory, Sources, and Applications. By J. T. SPRAGUE, M.S.T.E. Second edition, revised and enlarged, *with numerous illustrations*, crown 8vo, cloth, 15*s.*

The Practice of Hand Turning in Wood, Ivory, Shell, etc., with Instructions for Turning such Work in Metal as may be required in the Practice of Turning in Wood, Ivory, etc.; also an Appendix on Ornamental Turning. (A book for beginners.) By FRANCIS CAMPIN. Third edition, *with wood engravings*, crown 8vo, cloth, 6*s.*

CONTENTS:

On Lathes—Turning Tools—Turning Wood—Drilling—Screw Cutting—Miscellaneous Apparatus and Processes—Turning Particular Forms—Staining—Polishing—Spinning Metals—Materials—Ornamental Turning, etc.

Health and Comfort in House Building, or Ventilation with Warm Air by Self-Acting Suction Power, with Review of the mode of Calculating the Draught in Hot-Air Flues, and with some actual Experiments. By J. DRYSDALE, M.D., and J. W. HAYWARD, M.D. Second edition, with Supplement, *with plates*, demy 8vo, cloth, 7*s.* 6*d.*

Treatise on Watchwork, Past and Present. By the Rev. H. L. NELTHROPP, M.A., F.S.A. *With* 32 *illustrations*, crown 8vo, cloth, 6*s.* 6*d.*

CONTENTS:

Definitions of Words and Terms used in Watchwork—Tools—Time—Historical Summary—On Calculations of the Numbers for Wheels and Pinions; their Proportional Sizes, Trains, etc.—Of Dial Wheels, or Motion Work—Length of Time of Going without Winding up—The Verge—The Horizontal—The Duplex—The Lever—The Chronometer—Repeating Watches—Keyless Watches—The Pendulum, or Spiral Spring—Compensation—Jewelling of Pivot Holes—Clerkenwell—Fallacies of the Trade—Incapacity of Workmen—How to Choose and Use a Watch, etc.

Notes in Mechanical Engineering. Compiled principally for the use of the Students attending the Classes on this subject at the City of London College. By HENRY ADAMS, Mem. Inst. M.E., Mem. Inst. C.E., Mem. Soc. of Engineers. Crown 8vo, cloth, 2*s.* 6*d.*

Algebra Self-Taught. By W. P. HIGGS, M.A., D.Sc., LL.D., Assoc. Inst. C.E., Author of 'A Handbook of the Differential Calculus,' etc. Second edition, crown 8vo, cloth, 2*s.* 6*d.*

CONTENTS:

Symbols and the Signs of Operation—The Equation and the Unknown Quantity—Positive and Negative Quantities—Multiplication—Involution—Exponents—Negative Exponents—Roots, and the Use of Exponents as Logarithms—Logarithms—Tables of Logarithms and Proportionate Parts—Transformation of System of Logarithms—Common Uses of Common Logarithms—Compound Multiplication and the Binomial Theorem—Division, Fractions, and Ratio—Continued Proportion—The Series and the Summation of the Series—Limit of Series—Square and Cube Roots—Equations—List of Formulæ, etc.

Spons' Dictionary of Engineering, Civil, Mechanical, Military, and Naval; with technical terms in French, German, Italian, and Spanish, 3100 pp., and *nearly* 8000 *engravings*, in super-royal 8vo, in 8 divisions, 5*l.* 8*s.* Complete in 3 vols., cloth, 5*l.* 5*s.* Bound in a superior manner, half-morocco, top edge gilt, 3 vols., 6*l.* 12*s.*

Crown 8vo, cloth, with illustrations, 5s.

WORKSHOP RECEIPTS,

FIRST SERIES.

By ERNEST SPON.

Synopsis of Contents.

Bookbinding.
Bronzes and Bronzing.
Candles.
Cement.
Cleaning.
Colourwashing.
Concretes.
Dipping Acids.
Drawing Office Details.
Drying Oils.
Dynamite.
Electro - Metallurgy — (Cleaning, Dipping, Scratch-brushing, Batteries, Baths, and Deposits of every description).
Enamels.
Engraving on Wood, Copper, Gold, Silver, Steel, and Stone.
Etching and Aqua Tint.
Firework Making — (Rockets, Stars, Rains, Gerbes, Jets, Tourbillons, Candles, Fires, Lances, Lights, Wheels, Fire-balloons, and minor Fireworks).
Fluxes.
Foundry Mixtures.
Freezing.
Fulminates.
Furniture Creams, Oils, Polishes, Lacquers, and Pastes.
Gilding.
Glass Cutting, Cleaning, Frosting, Drilling, Darkening, Bending, Staining, and Painting.
Glass Making.
Glues.
Gold.
Graining.
Gums.
Gun Cotton.
Gunpowder.
Horn Working.
Indiarubber.
Japans, Japanning, and kindred processes.
Lacquers.
Lathing.
Lubricants.
Marble Working.
Matches.
Mortars.
Nitro-Glycerine.
Oils.
Paper.
Paper Hanging.
Painting in Oils, in Water Colours, as well as Fresco, House, Transparency, Sign, and Carriage Painting.
Photography.
Plastering.
Polishes.
Pottery—(Clays, Bodies, Glazes, Colours, Oils, Stains, Fluxes, Enamels, and Lustres).
Scouring.
Silvering.
Soap.
Solders.
Tanning.
Taxidermy.
Tempering Metals.
Treating Horn, Mother-o'-Pearl, and like substances.
Varnishes, Manufacture and Use of.
Veneering.
Washing.
Waterproofing.
Welding.

Besides Receipts relating to the lesser Technological matters and processes, such as the manufacture and use of Stencil Plates, Blacking, Crayons, Paste, Putty, Wax, Size, Alloys, Catgut, Tunbridge Ware, Picture Frame and Architectural Mouldings, Compos, Cameos, and others too numerous to mention.

London: E. & F. N. SPON, 125, Strand.
New York: 35, Murray Street.

Crown 8vo, cloth, 485 pages, with illustrations, 5*s*.

WORKSHOP RECEIPTS,

SECOND SERIES.

By ROBERT HALDANE.

Synopsis of Contents.

Acidimetry and Alkalimetry.
Albumen.
Alcohol.
Alkaloids.
Baking-powders.
Bitters.
Bleaching.
Boiler Incrustations.
Cements and Lutes.
Cleansing.
Confectionery.
Copying.
Disinfectants.
Dyeing, Staining, and Colouring.
Essences.
Extracts.
Fireproofing.
Gelatine, Glue, and Size.
Glycerine.
Gut.
Hydrogen peroxide.
Ink.
Iodine.
Iodoform.
Isinglass.
Ivory substitutes.
Leather.
Luminous bodies.
Magnesia.
Matches.
Paper.
Parchment.
Perchloric acid.
Potassium oxalate.
Preserving.

Pigments, Paint, and Painting: embracing the preparation of *Pigments*, including alumina lakes, blacks (animal, bone, Frankfort, ivory, lamp, sight, soot), blues (antimony, Antwerp, cobalt, cœruleum, Egyptian, manganate, Paris, Péligot, Prussian, smalt, ultramarine), browns (bistre, hinau, sepia, sienna, umber, Vandyke), greens (baryta, Brighton, Brunswick, chrome, cobalt, Douglas, emerald, manganese, mitis, mountain, Prussian, sap, Scheele's, Schweinfurth, titanium, verdigris, zinc), reds (Brazilwood lake, carminated lake, carmine, Cassius purple, cobalt pink, cochineal lake, colcothar, Indian red, madder lake, red chalk, red lead, vermilion), whites (alum, baryta, Chinese, lead sulphate, white lead—by American, Dutch, French, German, Kremnitz, and Pattinson processes, precautions in making, and composition of commercial samples—whiting, Wilkinson's white, zinc white), yellows (chrome, gamboge, Naples, orpiment, realgar, yellow lakes); *Paint* (vehicles, testing oils, driers, grinding, storing, applying, priming, drying, filling, coats, brushes, surface, water-colours, removing smell, discoloration; miscellaneous paints—cement paint for carton-pierre, copper paint, gold paint, iron paint, lime paints, silicated paints, steatite paint, transparent paints, tungsten paints, window paint, zinc paints); *Painting* (general instructions, proportions of ingredients, measuring paint work; carriage painting—priming paint, best putty, finishing colour, cause of cracking, mixing the paints, oils, driers, and colours, varnishing, importance of washing vehicles, re-varnishing, how to dry paint; woodwork painting).

London: E. & F. N. SPON, 125, Strand.
New York: 35, Murray Street.